

DDS Series Engineering Catalog

- Up to 36,000 CFM
- Titanium Enhanced Silica Gel Desiccant Wheel
- Suitable for Indoor or Outdoor Use
- Independent Control over Temperature and Humidity
- Substantially Improved IAQ
- High Energy Efficiency



The Humidity Expert

TABLE OF CONTENTS

Introduction.....	1
DDS Product Line	1
Munters Honeycombe® Wheel Technology	2
Overview.....	3
Available Unit Sizes and Options	3
DDS Product & Configurations	4
Model Numbers.....	4
Drycool Dehumidification System Capacities	5
20 Housing Modules	6
30 Housing Modules	7
Selection Process & Example	8-10
A Unit & Configuration	11
Equipment Data	12
A5 & A10 Unit Drawings	13
Appendix	
Wheel Data Chart	A1
Standard Wheel Performance	A2
Enthalpy Wheel Selection	A3
Sensible Heat Wheel Selection	A3
Drycool Dehumidification System Specifications	A4-A11

INTRODUCTION

Munters manufactures air conditioning systems for industrial and commercial environments that can benefit from reduced humidity levels. Using Munters HoneyCombe® wheel technology, DryCool system dehumidify and control air temperature separately ensuring proper control for space conditioning and comfort.


Today, indoor air quality has become a global environmental issue. In reaction, the leading professional organization of HVAC engineers, ASHRAE, has created new standards

for building operation, which are being incorporated into local building codes. As building operators seek to meet the new standards, they find that humidity in the increased levels of outside air creates control and comfort problems and that exhausting large volumes of conditioned air raises energy costs. DryCool systems address both of these problems. Markets currently using DryCool technology include supermarkets, ice arenas, schools, hotels, restaurants, office and retail space and many more.

DDS PRODUCT LINE

Munters, the world's leading manufacturer of desiccant dehumidification equipment, announces the Munters DDS—the DryCool Dehumidification System. The DDS offers the flexibility and integrity of a custom product, the convenience and value of a pre-configured system, backed by the international support and capabilities of the world's largest desiccant dehumidifier

manufacturer. The DDS features double wall construction, enclosed insulation, easily removable panels, component flexibility and an FRP pultrusion frame that ensures no thermal bridging by providing a true “no through metal” design. Standard DDS configurations of airflow and dehumidifier positions provide the flexibility to accommodate most applications.



A Munters DryCool Dehumidification System model number DDS-30-4. This system includes a desiccant dehumidification wheel, sensible energy recovery wheel, cooling and heating. An evaporative cooling section is included to increase system efficiency.


MUNTERS
HONEYCOMBE®
WHEEL
TECHNOLOGY

Munters equipment removes moisture from air by using a desiccant—a material that easily attracts and holds water vapor. The primary desiccant used in DryCool systems is Titanium Silica Gel. Titanium Silica Gel is an adsorbent. Water is attracted to the walls of many fine pores within the material. Munters has developed a patented method for manufacturing Titanium Silica Gel in a HoneyCombe® wheel form, which results in a strong and stable structure, yielding ideal drying performance in a wide range of applications. Because Titanium Silica Gel is a solid, insoluble desiccant, it is not possible to “wash out” the desiccant from the wheel. This means no special precautions are required even when it is exposed to air at 100% relative humidity. The permanent nature of the desiccant makes it possible to literally wash the wheel with water if dust or other particulate block the air passageways. Air passes through the HoneyCombe® wheel coming in contact with the desiccant. The wheel rotates slowly (6 to 10 rph) between two airstreams. The process air stream—the airstream being dehumidified—gives off its moisture to the desiccant. The process air is dry as it leaves the wheel. The humidity laden wheel rotates slowly into a second, smaller airstream which has been heated. This smaller exhaust airstream—

called the reactivation air—warms the desiccant.

The warmed desiccant gives off its moisture, which is then carried away by the reactivation air. The newly dried desiccant material is rotated back into the process airstream where it again begins to adsorb moisture. Munters equipment provides modulating control of the reactivation heat source based on the reactivation air leaving temperature. This internal modulation control works with the external call for dehumidification to provide proportional capacity based on the moisture load seen by the desiccant wheel. Capacity is closely matched to the load to minimize cycling, maximize efficiency, and to protect the wheel from extreme temperatures.

Cross contamination of the supply and exhaust/activation air streams is a concern when applying any type of wheel technology. In a Munters unit, the fans are located to provide a negative pressure in the reactivation cabinet to insure any airflow moves from the supply to the reactivation air stream. This prevents the transfer of moisture and contaminants from the exhaust airstream to the process airstream. To provide added performance the process and reactivation airstreams are separated by a radial bulb seal covered with a self lubricating graphite filled teflon to prevent moisture leakage between the two airstreams.



OVERVIEW

Munters offers a wide variety of system configurations to meet the stringent demands of dehumidification project requirements. The units are designed around the desiccant dehumidification module. This module consists of the desiccant wheel, process fan, reactivation heat source, and reactivation fan. Numerous desiccant wheel sizes are available to match the dehumidification requirements of specific applications. The DDS is available in many sizes and offers a wide variety of optional air conditioning modules.

The A unit is a basic dehumidifier used in installations requiring less than 2500 CFM. Please see the descriptions below for a detailed outline of the sizes and options available.

DryCool Dehumidification System

This DDS is a modular product line that provides consistent construction between all Munters dehumidification units world wide. It utilizes two inch double wall construction. It is available in up to 36,000 CFM supply air and can dehumidify up to 10,000 CFM. Options include sensible heat wheel, enthalpy recovery wheel, cooling coils, various heat options, and many others.

A Unit

This unit is designed for small dehumidification applications. It is available in a nominal 1750 CFM and 2500 CFM. It is a single wall unit and includes only the basic dehumidification module described above. No options are available for this basic unit configuration.

Available Unit Sizes and Options

PRODUCTS	DDS	A UNITS	
		A5	A10
Supply CFM	3000-36,000	1750	2500
Wheel Size Diameter & Depth	1000mm x 200, 400mm 1300mm x 200, 400mm 1500mm x 200, 400mm	630mm x 200mm	750mm x 400mm
Reactivation Options	Natural Gas/ Propane/ Steam/ Hot Water/ Elec.	Natural Gas/ Electric	Natural Gas/ Propane/ Steam/ Hot Water/ Elec.
Fan Hp (supply/reactivation)	Up to 50 Hp	3.5 Hp/1 Hp	3 Hp/2 Hp
Heating Options	Steam/ Hot Water/ Indirect Gas to 1600 MBH	Not Available	Not Available
Cooling Options	Pre cooling DX or CHW Post cooling DX or CHW	Not Available	Not Available
Condensing Units	Split Systems Packaged up to 100 Tons	Not Available	Not Available
Energy Recovery	Enthalpy Pre cooling Sensible Post cooling	Not Available	Not Available

DDS PRODUCT

The DDS is a modular product that is built up around the desiccant dehumidifier module. It consists of two housing sizes—the 20 and 30—and a variety of modules that offer a significant level of flexibility. The modules available in the 20 and 30 housings are shown in the next two pages. Although the product is constructed in a modular fashion, the following five configurations

provide an engineered solution for most commercial dehumidification applications. Modules can be added or removed from these standard configurations to add further flexibility to the product. The capacity of the configurations depends upon the components included. The DDS configuration capacities are shown on page 5.

CONFIGURATIONS


Stand alone dehumidifier. Nominal dehumidifier capacity of 5,000, 7,500 and 10,000 scfm. 0-100% makeup air. Return and makeup air connections included.

Dehumidification system with bypass. Cooling and heating options available. 0-100% makeup air. Nominal total supply air volume up to 24,000 scfm. Dehumidification capacity up to 10,000 cfm.

Dehumidification system with total energy recovery. Cooling and heating options available. 0-100% makeup air. Nominal total supply air volume up to 15,000 scfm. Dehumidifier capacity up to 10,000 cfm.

Dehumidification system with sensible energy recovery. Cooling and heating options available. 0-100% makeup air. Nominal total supply air volume up to 10,000 scfm. Dehumidifier capacity up to 10,000 cfm.

Dehumidification system where large airflow is required for sensible heating and cooling. Pretreatment of makeup air not available. Nominal total supply volume up to 36,000 cfm. Dehumidifier capacity up to 10,000 cfm. Includes process and supply fan to minimize required fan horsepower. Includes return and makeup air connections in dehumidifier module which is a modified version of Module A for selection and sizing purposes.



MODEL NUMBERS

The model number is used to indicate the housing size and the system configuration. For example, a configuration 2 system utilizing a size 30 housing to process 24,000 scfm is a DDS-30-2.

LEGEND

 Active Desiccant Dehumidification Wheel	 Cooling Coil	 Enthalpy Wheel	 Sensible Energy Recovery Wheel
 Filter	 Heater	 Fan	 Evaporative Cooler
 Process Air	 Reactivation/ Exhaust Air		

DRYCOOL DEHUMIDIFICATION SYSTEM CAPACITIES

Config.	Housing	Dehumidifier Wheel	Max Dehumid. Volume (cfm)	Max Supply Volume (cfm)	Max Reactivation Burner Input (MBH)	Maximum Fan Horsepower (hp)				DH Module FLA @ 460/3/60	Supply Fan FLA @ 460/3/60
						Supply	Process	React	Exhaust		
1	20	1001	5000	5000	400		5	2		10.5	
	20	1000	5000	5000	400		7.5	3		14.4	
	20	1301	7500	7500	750		7.5	5		16.7	
	20	1300	7500	7500	750		10	5		19.5	
	30	1501	10000	10000	750		10	5		19.5	
	30	1500	10000	10000	750		15	7.5		28.1	
2	20	1001	5000	12000	400	25		2		4.6	29.7
	20	1000	5000	12000	400	25		3		5.6	
	20	1301	7500	12000	750	25		5		7.9	
	20	1300	7500	12000	750	25		5		7.9	
	30	1001	5000	24000	400	40		2		4.6	47.7
	30	1000	5000	24000	400	40		3		5.6	
	30	1301	7500	24000	750	40		5		7.9	
	30	1300	7500	24000	750	40		5		7.9	
	30	1501	10000	24,000	750	40		5		7.9	
	30	1500	10000	24,000	750	40		7.5		10.8	
3	20	1001	5000	5000	400	10		2	5	4.6	11.6
	20	1000	5000	5000	400	10		3	5	5.6	
	20	1301	5000	7500	750	10		5	5	7.9	
	20	1300	5000	7500	750	10		5	5	7.9	
	30	1001	5000	15000	400	40		2	15	4.6	47.7
	30	1000	5000	15000	400	40		3	15	5.6	
	30	1301	7500	15000	750	40		5	15	7.9	
	30	1300	7500	15000	750	40		5	15	7.9	
	30	1501	10000	15000	750	40		5	15	7.9	
	30	1500	10000	15000	750	40		7.5	15	10.8	
4	20	1001	3000	3000	400	5		5		7.9	5.9
	20	1000	5000	5000	400	10		10			
	30	1501	7500	7500	750	10		10		13.6	11.6
	30	1500	10000	10000	750	15		20		25.8	
5	20	1001	5000	12000	400	15	5	5		13.8	17.3
	20	1000	5000	12000	400	15	5	5		13.8	
	20	1301	7500	12000	750	15	5	5		13.8	
	20	1300	7500	12000	750	15	7.5	5		16.7	
	30	1501	10000	22000	750	30	7.5	5		16.7	35.2
	30	1500	10000	22000	750	30	10	7.5		22.4	
	30	1501	10000	36000	750	50	10	5		19.5	58
	30	1500	10000	36000	750	50	10	7.5		22.4	


Process fan moves air stream that passes through desiccant wheel and is located in the dehumidifier housing.

Supply fan moves total airstream and is located in a separate plenum.

System can be equipped with either or both fans depending upon system configuration.

DH Module FLA includes process, reactivation and desiccant wheel drive motors. Also includes control circuit.

SIZE 20
HOUSING
MODULES




	MODULE	LENGTH	WEIGHT	MAX FLA @ 460/3/60
A	Dehumidifier Module (includes process fan)	123	3850	(4)
B	Dehumidifier Module with Bypass (requires supply fan module H)	123	3500	(4)
C	Enthalpy Module	92	2000	7
D	Cooling/Heating Module (1) up to 10000 cfm	31	600	0
E	Staggered Coil Module up to 12000 cfm	61	1250	0
F	Sensible Wheel Module	17	1150	1
G	Post Cool, Post Heat , Evap Cool Module (2)	58	2100	2
H	Supply Fan Module (Downblast, End, Side Discharge) (3)	61	1228	(4)
I	Indirect Fired Post Heater (Rated at Input, Efficiency = 80%)			
	400, 800 MBH with Downblast (fits in Supply Fan Module H)	0	622	2
	400, 800 MBH End or Side Discharge	61	1180	2
J	Mixing Section	31	280	0
K	Access Sections or Blank Section	31	280	0
L	3 - 30 Ton Condensing Unit	61	1900	67
	35 - 40 Ton Condensing Unit	92	2700	92

To calculate system length sum module lengths and add 4 inches.
Height is 70 inches, width is 80 inches for all modules.
Return and outside air pass through 30% filters.

- (1) Can accommodate up to 10 rows of cooling and 2 rows of heating, cannot be used with Module F.
- (2) Module only for systems utilizing sensible wheel. Any component can be removed from Module G if not required.
- (3) For systems without bypass the fan is mounted in the dehumidifier module.
- (4) DH module and supply fan FLA is shown on DryCool Dehumidification System Capacities table on page 5.

SIZE 30
HOUSING
MODULES



	MODULE	LENGTH	WEIGHT	MAX FLA @ 460/3/60
A	Dehumidifier Module (includes process fan)	123	4850	(4)
B	Dehumidifier Module with Bypass (requires supply fan module H)	123	4450	(4)
C	Enthalpy Module	123	3400	19
D	Cooling/Heating Module (1) up to 24000 cfm	31	1000	0
E	Staggered Coil Module up to 36000 cfm	61	1200	0
F	Sensible Wheel Module	114	1800	1
G	Post Cool, Post Heat , Evap Cooling Module (2)	51	2650	2
H	Supply Fan Module (Downblast, End , Side Discharge) (3)	61	2200	(4)
I	Indirect Fired Post Heater (Rated at Input, Efficiency = 80%)			
	400, 800 MBH Downblast up to 20000 cfm (fits in Supply Fan Module H)	0	500	2
	400, 800, 1200 MBH Side Discharge	0	750	3
	400 and 800 MBH Downblast over 20000 cfm, 1200, 1600 MBH Downblast	61	1850	4
	400, 800, 1200, 1600 MBH End Discharge	61	2400	4
J	Mixing Section	31	360	0
K	Access Sections or Blank Section	31	360	0
L	10 - 30 Ton Condensing Unit	61	2150	62
	35 - 60 Ton Condensing Unit	92	3550	123
	65 - 80 Ton Condensing Unit	123	4700	166
	85 -100 Ton Condensing Unit	153	5750	208

To calculate unit length total module lengths and add 4 inches.

Height is 101 inches, width is 96 inches for all modules.

Return and Outside air pass through 30% filters.

- (1) Can accommodate up to 10 rows of cooling and 2 rows of heating, cannot be used with Module F.
- (2) Module only for systems utilizing sensible wheel. Any component can be removed from Module G if not required.
- (3) For systems without bypass the fan is mounted in the dehumidifier module.
- (4) DH module and supply fan FLA is shown on DryCool Dehumidification System Capacities table on page 5.

SELECTION PROCESS

The first step of the selection process is the determination of the internal latent load. The internal latent load includes such sources as personnel, air infiltration, standing water and open flames. In many cases most of these elements can be reduced to negligible levels.

The individual load elements are added to determine the total internal latent load. The required delivered air condition to the controlled space can be calculated once the internal latent and sensible loads have been determined. The latent work performed by the dehumidification system will include the moisture removal required in the conditioned space and the moisture removed from the outside air.

Compare the calculated load with the Wheel Data Chart located in the Appendix. This will determine the approximate wheel size required to meet the load. More precise performance data is available in the Wheel Performance Charts located in the Appendix. The selection of the wheel and the specific performance requirement will provide the air quantity that is required through the desiccant wheel. It is not uncommon for only a portion of the total airstream to be processed through the desiccant rotor. This is attributable to a number of factors. Munters wheels outperform other desiccant rotors and can often achieve more moisture removal with smaller diameter or thinner wheels. This results in more moisture removal capacity with lower energy consumption. Also, the total airflow is often determined by makeup air or sensible load requirements. If the dehumidification load is small enough, processing a portion of the total airstream is sufficient to appropriately control space humidity.

The performance of the desiccant wheel can be enhanced by adding pre-cooling. This will reduce the quantity of air required for dehumidification. Pre-cooling can be achieved with a cooling coil or an enthalpy wheel if exhaust recovery is available.

As moisture is adsorbed by the desiccant rotor, the temperature of the air rises. A sensible wheel can be used to lower the leaving process air temperature. The sensible wheel can utilize either exhaust or outside air. Performance of enthalpy and sensible recovery wheels is shown in the Appendix.

The A unit does not offer options to provide cooling and heating. It is typically used in conjunction with other air conditioning units or duct mounted coils to meet the requirements of the sensible load. The DDS has an extensive list of options to meet the sensible requirements of the space load and air flow requirements. Please review the configuration options in the DDS section for more information.

It is important to note that performing the latent cooling separate from the sensible cooling may require a rethinking of air quantities supplied to the space. The desiccant unit can be utilized as a 100% outside air unit or with return air similar to conventional equipment. The flexibility provided by this decoupling of the latent and sensible capacity needs to be utilized to maximize the effectiveness of the overall system.

Consult a DryCool Applications Engineer for detailed performance selection. 1-800-MUNTERS

EXAMPLE

Outside design summer: 95°F db, 75°F wb, 99 gr/lb
 Indoor design summer: 75°F db, 50% rh, 65 gr/lb
 Supply air (SA) volume: 15,000 cfm
 Return air (RA) volume: 2,000 cfm
 Return/exhaust air condition: 80°F db, 67°F wb, 79 gr/lb
 Internal latent load: 91,000 btuh

Outside design winter: 10°F db
 Indoor design winter: 70°F db
 Outside air (OA) volume: 13,000 cfm
 Exhaust air (EA) volume: 12,000 cfm
 Internal sensible cooling load: 220,000 btuh
 Internal sensible heating load: 712,000 btuh

LOAD CALCULATION—The internal load calculations are a combination of the loads generated by people, lighting, infiltration, etc. and should not include the outside air load. The internal load should also take into account any cooling and/or heating credits available (i.e. display cases, ice surface, etc.).


The delivered air conditions to satisfy the internal loads are calculated in the following manner:

Internal Latent: Delivered Moisture = Indoor Moisture – [(internal latent load x 7000)/(4.5 x SA volume x 1050)] =
 $65 - [(91,000 \times 7000) / (4.5 \times 15,000 \times 1050)] = 56.0 \text{ gr/lb}$
 Internal Sensible (cooling): Delivered Temp = Indoor Temp – [internal sensible load / (SA volume * 1.08)] =
 $75 - [220,000 / (15,000 * 1.08)] = 61.4^\circ\text{F db}$
 Internal Sensible (heating): Delivered Temp = Indoor Temp + [internal sensible load / (SA volume * 1.08)] =
 $70 + [(712,000) / (15,000 * 1.08)] = 114.0^\circ\text{F db}$

COMPONENTS—Exhaust air is available for energy recovery. The use of an enthalpy (sensible and latent) recovery wheel results in increased dehumidification capacity and lower operating costs. The enthalpy wheel acts as a pre-cooler, transferring sensible and latent heat from the outside airstream to the exhaust air stream, reducing the total outside air load. The enthalpy wheel alone is not capable of satisfying the entire external and internal loads, therefore the use of desiccant dehumidification, mechanical cooling and heating are still required.

Based upon this determination, Configuration 3 is selected. The result is a Model DDS-30-3. The following components are shown in sequential order from air entering to air leaving.

- Module C – Enthalpy Wheel
- Module B – Dehumidifier module with bypass
- Module D – Cooling Coil
- Module H – Supply fan
- Module I – Indirect fired post heater
- Module L – Condensing unit



ENTHALPY WHEEL—The outside air is drawn through filters and the enthalpy wheel first. The leaving air condition of the enthalpy wheel is a product of the wheel efficiency and the enthalpy difference of the two airstreams. Select the enthalpy wheel efficiency from the Enthalpy Wheel Selection Chart in the Appendix.

The ratio of outside air to exhaust air = $13,000 / 12,000 = 1.1$
 From the chart, the wheel efficiency at 13,000 cfm and 1.1 is 66%.

Leaving air temperature = OA temp – [(OA temp – EA temp) x Wheel efficiency] =
 $95 - [(95 - 80) \times .66] = 85.1^\circ\text{F}$
 Leaving air moisture = OA moisture – [(OA moisture – EA moisture) x Wheel efficiency] =
 $99 - [(99 - 79) \times .66] = 85.8 \text{ gr/lb}$

EXAMPLE CONTINUED (Component Performance Selection)

DESICCANT WHEEL—The 13,000 cfm processed through the enthalpy wheel is blended with 2000 cfm of return air. The blend air (BA) condition is 15,000 cfm at 84.3°F, 84.9 gr/lb.

Select the desiccant wheel from the Wheel Data Chart on page A1 of the appendix. Start by choosing the largest desiccant wheel available for the BA volume. Wheel size should be adjusted if significant excess capacity is present. The 1500 is a 400mm desiccant wheel that can process up to 10,000 cfm. The remaining 5000 cfm will be bypassed. Starting with the maximum cfm, determine the face velocity in feet per minute (10,000/12.5 = 800 fpm). From the 400mm Wheel Performance Chart on page A2 the process air leaving air (PAL) moisture = 40 gr/lb.

In the process of adsorbing moisture in the desiccant wheel the temperature of the air increases as latent heat is converted into sensible heat. The process air temperature rise is equal to approximately 0.8°F per gr/lb removed. PAL Temp = BA Temp + [(0.8 * (BA moisture – PAL moisture))] = 84.3 + [(84.9 – 40) x .8] = 120.2°F

The air processed through the dehumidifier blends with the bypass air. The blended condition = 108.2°F , 54.9 gr/lb

SUPPLY FAN—Determine the supply fan horsepower on page 5. The supply fan horsepower for a configuration 3, housing size 30 is 40 hp. To estimate heat added to the airstream multiply the fan motor hp by 2544 = 40 x 2544 = 101,760 btuh. Supply fan temperature rise = [(motor heat/(1.08 * SA volume))] = [(101,760/(1.08 x 15000))] = 6.3°F

COOLING—The temperature of the air entering the coil is 108.2°F. Based on the load calculations air at 61.4°F is required to satisfy the space sensible load. In this example the supply fan is located after the post cooling coil. Therefore the condition leaving the coil = 61.4 – 6.3 = 55.1°F

Coil btuh = (Coil entering temp – Delivered air temp) x SA volume x 1.08 =
(108.2 – 55.1) x 15,000 x 1.08 = 860,220 btuh or 71.7 tons.

HEATING—The outside air enters the enthalpy wheel first. Use the same method as before to determine the leaving air temperature from the enthalpy wheel.

LA temp = OA temp + [(Return air temp – Outside air temp) x Wheel efficiency] =
10 + [(70 – 10) x .66] = 49.6°F

This air is blended with return air. The resulting temperature = 52.3°F

Dehumidification in the winter is not required and all of the air will bypass the desiccant wheel. Temperature rise across fan = 6.3°F. Post heater entering air temperature = 52.3 + 6.3 = 58.6°F. Based on the load calculations the required air temperature is 114°F to satisfy the space-heating load.

Heating btuh = (Delivered air temp – Entering air temp) x SA volume x 1.08 =
(114.0 – 58.6) x 15,000 x 1.08 = 897,480 btuh.

Heater efficiency = 80%. Heater size = Heating btuh/heater efficiency = 897,480/.8 = 1,121,850 btuh

SIZE & ELECTRICAL DATA—To determine dimensions, weight and FLA of the selected system, use the table on page 7.

	MODULE	LENGTH	WEIGHT	FLA
2	Dehumidifier Module with Bypass (requires supply fan module #8)	123	4450	10.8
3	Enthalpy Module	123	3400	19
4	Cooling/Heating Module (1)	31	1000	0
8	Supply Fan Module (Downblast, End , Side Discharge) (3)	61	2200	47.7
9	Indirect Fired Post Heater (Rated at Input, Efficiency = 80%)			
	1200, 1600 MBH Downblast	61	1850	4
12	65-80 Ton Condensing Unit	123	4700	166
	Totals	522	17600	247.5

A UNIT

The A unit is the smallest and most basic commercial unit. It includes only a dehumidifier section. No cooling coils, heating coils, or other options are available with these units. The A-5 unit is designed for indoor installation only, while the A-10 unit can be installed indoors or outdoors. The drawing below provides the basic airflow for the A unit.

The units include a Titanium Silica Gel desiccant wheel. The

reactivation can be direct fired natural gas or electric for the A-5 unit and direct fired natural gas, propane, steam, hot water, or electric for the A-10 unit.

Component Options


- A-5 has none
- A-10 has none

Reactivation Options

- A-5 has Natural Gas and Electric
- A-10 has Natural Gas, Propane, steam, Hot Water, and Electric



A UNIT CONFIGURATION




LEGEND

■ Active Desiccant Dehumidification Wheel	■ Heater	■ Fan
■ Filter	--- Reactivation/ Exhaust Air	— Process Air


EQUIPMENT DATA

EQUIPMENT	A-5	A-10
Supply Air Volume (cfm)	1750	2500
Unit Weight (lbs)	750	1400
PROCESS FAN		
Size	10x110 SWSI	13x90 SWSI
Type / Class	BAF / II	BAF / II
Air Volume (cfm)	1750	2500
Total Static Pressure (wg)	5	4.5
External Static Pressure (wg)	3.5	1.5
Motor hp	3.5	3
REACTIVATION FAN		
Size	6 SWSI	12x100 SWSI
Type / Class	FC / II	BAF / II
Air Volume (cfm)	350	900
Total Static Pressure (wg)	3.5	6.5
External Static Pressure (wg)	1.5	0.5
Motor hp	1	2
REACTIVATION HEATER		
Gas		
Capacity (max btuh input)	80,000	200,000
Stages of Capacity	3	Modulating
Natural Gas Pressure Required(wg)	6-15" WG	6-15" WG
Propane Gas Pressure Required(wg)	N/A	11-15" WG
Electric		
Capacity	15.3 KW	50 KW
Stages of Capacity	2	3
DESICCANT WHEEL		
Wheel Diameter (in.)	25	30
Nominal Moisture Removal (lb/hr)	25	75
FILTERS		
Type	30% Pleated	30% Pleated
Number / Size	(1) 12x20x2 (1) 20x25x2	(4) 16x20x2
ELECTRICAL DATA		
Gas Reactivation		
System Voltage (V/P/H)	460/3/60	460/3/60
Control Circuit Voltage	24	110
Process Motor Amps	4.60	4.00
Reactivation Motor Amps	1.35	2.90
Control Transformer	0.25	0.54
Unit FLA	6.20	7.44
Unit MCA	7.35	8.44
Unit MOP	11.95	12.44
Disconnect Size	16	16
Electric Reactivaion		
System Voltage (V/P/H)	460/3/60	460/3/60
Control Circuit Voltage	24	110
Process Motor Amps	2.60	4.00
Reactivation Motor Amps	0.80	2.90
Control Transformer	0.43	0.54
Electric Heater		
Unit FLA	23.13	70.44
Unit MCA	23.78	71.44
Unit MOP	26.38	74.07
Disconnect Size	30	100


A5 UNIT DRAWINGS



LEFT SIDE




FRONT VIEW




PLAN VIEW

WIDTH	DEPTH	HEIGHT	PROCESS INLET	REACT. OUTLET	REACT. INLET	PROCESS OUTLET	WEIGHT
(A)	(B)	(C)	(G x H)	(D)	(F)	(E)	
63 ¹³ / ₁₆ "	37 ³ / ₄ "	55 ⁵ / ₈ "	24x19 ¹ / ₁₆ "	6" dia	10" dia	12" dia	750 lbs


A10 UNIT DRAWINGS



FRONT VIEW



BACK VIEW



PLAN VIEW

WIDTH	DEPTH	HEIGHT	PROCESS INLET	REACT. OUTLET
(A)	(B)	(C)	(DxE)	(FxG)
103 ³ / ₁₆ "	61 ³ / ₈ "	55 ³ / ₈ "	41 ³ / ₈ x10 ¹ / ₁₆ "	22 ¹¹ / ₁₆ x14 ³ / ₁₆ "

REACT. INLET	PROCESS OUTLET	MAKEUP INLET	CAB WIDTH	WEIGHT
(HxI)	(JxK)	(LxM)	(N)	
14 ⁷ / ₈ x14 ⁷ / ₈ "	26 ³ / ₈ x13 ¹ / ₄ "	12 ¹ / ₆ x12 ³ / ₁₆ "	84 ⁹ / ₁₆ "	1400 lbs.

APPENDIX

WHEEL DATA CHART

Wheel Designation	Nom CFM	Dia (mm)	Depth (mm)	Face Area (sq. ft.)
A5	1750	630	100	2.55

Wheel Designation	Entering Temp F	80	67	55
	Entering Grains	80	80	62
A5	Latent Cooling	27,370	29,750	28,560
	Leaving grains	57	55	38
	Leaving Temp F	102	89	76

Wheel Designation	Nom CFM	Dia (mm)	Depth (mm)	Face Area (sq. ft.)
A10	2500	750	400	3.13
1001	5000	1000	200	6.25
1000	5000	1000	400	6.25
1301	7500	1300	200	9.25
1300	7500	1300	400	9.25
1501	10000	1500	200	12.5
1500	10000	1500	400	12.5

Formulas:

Q sensible =
1.08 x CFM x delta temperature; at standard air

Q latent =
0.68 x CFM x delta grains; at standard air

Temperature rise approx. =
0.8 x humidity depression in gr/lb

Wheel Designation	Entering Temp F	85	85	95	80	77	73	69	67	55
	Entering Grains	135	120	105	80	135	120	105	80	62
A10	Latent Cooling	108,460	101,660	76,160	80,750	118,830	116,960	114,410	97,920	86,360
	Leaving grains	71.2	60.2	60.2	32.5	65.1	51.2	37.7	22.4	11.2
	Leaving Temp F	137	134	133	119	133	128	123	113	95
1001	Latent Cooling	182,580	171,700	126,480	139,740	205,700	204,680	198,900	167,620	154,700
	Leaving grains	81.3	69.5	67.8	38.9	74.5	59.8	46.5	30.7	16.5
	Leaving Temp F	126	124	125	113	123	118.6	114	105	91
1000	Latent Cooling	216,920	203,320	152,320	161,500	237,660	233,920	228,820	195,840	172,720
	Leaving grains	71.2	60.2	60.2	32.5	65.1	51.2	37.7	22.4	11.2
	Leaving Temp F	137	134	133	119	133	128	123	113	95
1301	Latent Cooling	273,870	257,550	189,720	209,610	308,550	307,020	298,350	251,430	232,050
	Leaving grains	81.3	69.5	67.8	38.9	74.5	59.8	46.5	30.7	16.5
	Leaving Temp F	126	124	125	113	123	118.6	114	105	91
1300	Latent Cooling	325,380	304,980	228,480	242,250	356,490	350,880	343,230	293,760	259,080
	Leaving grains	71.2	60.2	60.2	32.5	65.1	51.2	37.7	22.4	11.2
	Leaving Temp F	137	134	133	119	133	128	123	113	95
1501	Latent Cooling	365,160	343,400	252,960	279,480	411,400	409,360	397,800	335,240	309,400
	Leaving grains	81.3	69.5	67.8	38.9	74.5	59.8	46.5	30.7	16.5
	Leaving Temp F	126	124	125	113	123	118.6	114	105	91
1500	Latent Cooling	433,840	406,640	304,640	323,000	475,320	467,840	457,640	391,680	345,440
	Leaving grains	71.2	60.2	60.2	32.5	65.1	51.2	37.7	22.4	11.2
	Leaving Temp F	137	134	133	119	133	128	123	113	95

STANDARD WHEEL PERFORMANCE


To calculate the process air leaving moisture:

1. Choose the model size and calculate the process air velocity.
2. Select proper wheel performance chart based on wheel depth (400 mm or 200 mm)
3. Enter the wheel performance curves at the process air inlet moisture.
4. Proceed vertically to intersect the process inlet temperature curve.
5. Move horizontally to the left, intersecting the reactivation heated temperature.
6. Proceed down vertically to intersect the process air face velocity line.
7. Move horizontally to the right edge of the chart to find the moisture content of the process air as it leaves the dehumidifiers.


To calculate the process leaving air temperature:

The temperature rise across the desiccant rotor is approximately 0.8°F per gr/lb of moisture removal.

400mm Wheel Performance



200mm Wheel Performance



Consult Factory for Detailed Performance Selection
1-800-MUNTERS

ENTHALPY WHEEL SELECTION

Size 120

ENTHALPY WHEEL EFFICIENCY								
Supply Air CFM	Pressure Drop inches w.g.	Ratio of Supply air to Exhaust air						
		0.9	1	1.1	1.2	1.3	1.4	1.5
1,750	0.24	87%	83%	80%	76%	72%	69%	65%
2,000	0.27	83%	81%	77%	75%	71%	67%	64%
2,500	0.34	82%	79%	76%	73%	69%	66%	63%
3,000	0.41	79%	76%	73%	70%	67%	64%	61%
3,500	0.50	77%	74%	71%	68%	65%	62%	59%
3,750	0.53	76%	73%	70%	67%	64%	61%	59%
4,000	0.57	72%	70%	67%	65%	63%	60%	58%
4,500	0.63	71%	69%	66%	64%	62%	59%	57%
5,000	0.69	70%	68%	65%	63%	61%	58%	56%

Size 200

ENTHALPY WHEEL EFFICIENCY								
Supply Air CFM	Pressure Drop inches w.g.	Ratio of Supply air to Exhaust air						
		0.9	1	1.1	1.2	1.3	1.4	1.5
5,000	0.24	87%	83%	80%	76%	72%	69%	65%
6,000	0.27	83%	81%	77%	75%	71%	67%	64%
7,000	0.34	82%	79%	76%	73%	69%	66%	63%
8,000	0.39	80%	77%	74%	71%	67%	64%	61%
9,000	0.46	78%	75%	72%	69%	66%	63%	60%
10,000	0.50	77%	74%	71%	68%	65%	62%	59%
11,000	0.53	76%	73%	70%	67%	64%	61%	59%
12,000	0.57	72%	70%	67%	65%	63%	60%	58%
13,000	0.63	71%	69%	66%	64%	62%	59%	57%
14,000	0.69	70%	68%	65%	63%	61%	58%	56%
15,000	0.75	69%	67%	64%	62%	60%	57%	55%

SENSIBLE HEAT WHEEL SELECTION

Size 120

HEAT WHEEL EFFICIENCY							
Supply Air CFM	Ratio of Supply air to Exhaust air						
	0.9	1	1.1	1.2	1.3	1.4	1.5
2,000	85%	81%	78%	75%	71%	67%	63%
2,500	82%	79%	75%	66%	69%	65%	62%
3,000	78%	75%	72%	70%	67%	64%	61%

Size 135

HEAT WHEEL EFFICIENCY							
Supply Air CFM	Ratio of Supply air to Exhaust air						
	0.9	1	1.1	1.2	1.3	1.4	1.5
3,500	78%	75%	72%	70%	67%	64%	61%
4,000	77%	74%	71%	69%	66%	62%	60%
4,500	76%	73%	70%	67%	65%	62%	59%
5,000	73%	70%	67%	65%	63%	60%	57%

Size 170

HEAT WHEEL EFFICIENCY							
Supply Air CFM	Ratio of Supply air to Exhaust air						
	0.9	1	1.1	1.2	1.3	1.4	1.5
5,000	83%	79%	77%	73%	70%	66%	63%
6,000	80%	77%	73%	70%	67%	64%	61%
7,000	77%	74%	71%	69%	66%	62%	60%
7,500	75%	72%	69%	68%	65%	60%	59%

Size 200

HEAT WHEEL EFFICIENCY							
Supply Air CFM	Ratio of Supply air to Exhaust air						
	0.9	1	1.1	1.2	1.3	1.4	1.5
8,000	80%	77%	74%	71%	68%	65%	62%
9,000	77%	74%	71%	69%	66%	62%	60%
10,000	76%	73%	70%	68%	65%	61%	59%

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

Part One: General

1) Warranty/Guarantee

- A) The DryCool Dehumidification System (DDS) and any auxiliary components provided by the manufacturer shall be warranted free from defects in workmanship or material for a period of 13 months from the date the equipment is shipped from the manufacturer's plant, or for a period of 12 months from the date of documented start up, whichever comes sooner. If any defects appear under this warranty, the manufacturer shall be notified by the owner, and the manufacturer shall provide appropriate replacement parts at no cost to the owner other than freight. The owner shall be responsible for labor performed in replacing parts provided by the manufacturer.
- B) Honeycombe® Wheels
Munters warrants its Titanium-enhanced Silica Gel Honeycombe® wheels to be free from defects in workmanship and material for a period of five years commencing thirty (30) days from the date of shipment by Munters.
- C) Unit shall be ETL listed.

Part Two: Product

1) Housing

A) Unit Base

- 1) Unit base shall be bolted steel construction with formed 12 gauge galvanized steel channel around the outside perimeter and reinforced with galvanized steel cross members bolted on centers not exceeding 31 inches. Base shall have lifting holes or brackets as required.

B) Unit Case

- 1) The unit casing shall be constructed using a double wall panel and frame system (as described below) for torsional rigidity. This includes walls, floors and ceilings. This system shall not contain any through metal. The unit casing shall also meet the following criteria based on ASTM E84-90 (Standard Test Method for Surface Burning of Building Materials).

Flame spread = 25
Smoke index = 50

- 2) The frame system components shall be constructed of fiberglass reinforced plastic (FRP) pultruded members. Horizontal frame members shall be supported along their length by intermediate supports and internal partitions. Through metal systems shall not be allowed. To avoid either condensation, heat loss or loss of cooling capacity, each panel shall be 2 inches thick and constructed such that there are no through metal connections between the exterior surface and the interior surface. The interior casing shall be 22-gauge corrosion resistant hot dipped G-90 galvanized steel. The exterior casing shall be 22-gauge corrosion resistant galvalume. Panels shall be foam injected into individual panels with a density of 2-1/2 lb/ft³. The heat transfer rate through casing walls shall be less than 0.0625 Btu/sq. ft./°F equivalent to an R-value of 14. This construction shall be suitable for a 50°F difference as tested between process air dry bulb temperature and the dew point of the air surrounding the plenum. The unit casing shall be manufactured and guaranteed as an air and vapor tight system. There shall be a gasket system that seals the panels to the structure. Fixed panels shall be provided with flat closed cell neoprene. Doors and plug panels shall be provided with closed cell foam polyvinyl chloride seals.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

C) Access Doors and Plug Panels

- 1) Access doors will be provided as indicated on the drawings. Doors shall be rigid double wall construction and shall use heavy-duty hinges with lockable latches on each door. Doors shall be a minimum of 30.5" in width and be the full height unit plenum. Doors shall be of the same construction as panels. Hinges shall be installed by locating hinges no more than 36 inches on center from hinge to hinge. Door latches shall be capable of being fully tightened against gasket surfaces. All major components such as coils, filters, blowers, etc., within the air handling structure shall be easily removable through access panels without dismantling plenums or distributing ductwork. Equipment that requires disassembly of components rather than access through removable or hinged panels shall not be acceptable. The unit casing shall include access panels for inspection and for any maintenance required by the operating and maintenance manual. Panels without gaskets shall not be acceptable.

D) Weather Protection

- 1) The dehumidification system shall be capable of continuous outdoor operation, the air inlets shall be protected from flowing water by either mist eliminators or connected duct work. Consequently, all access panels shall be weather tight, as shall all joints between casing and electrical conduits and between the unit casing and any components mounted in separate enclosures. For outdoor units a roof shall be fabricated using galvalume steel standing seam construction.

2) Desiccant Wheel

The desiccant wheel media shall be a monolithic, extended-surface contact medium, fabricated entirely of inert, inorganic binders and glass fibers formed into narrow passages in the direction of airflow. The wheel shall be non-toxic. It shall also meet the following requirements:

The process and reactivation air streams shall be separated by full content air seals and internal partitions so that the humid reactivation air does not mix with the dry process air. The proposed equipment shall meet the following minimum requirements:

A) Wheel Face Seals

For units with desiccant wheels under 61" in diameter, the dehumidifier shall have full-face seals on both the process air entering and the process air leaving sides of the wheel. These shall seal the entire perimeter of both air streams as they enter and leave the wheel. Partial seals shall not be acceptable. The seals shall be the silicone rubber bulb-type, with a protective strip of low-friction, abrasive-resistant surface to extend seal life and reduce the force needed to turn the desiccant wheel. Neither wiper-type seals nor brush-type nor any non-contact-type seal shall be acceptable. The seals shall be documented to have a minimum working life of 25,000 hours of normal operation.

B) Materials

The glass fibers which form the support matrix shall be made from uniform continuous strands larger than five microns in diameter which are nonrespirable and are not considered a possible health risk by the International Agency for Research on Cancer (IARC).

C) Flame spread and smoke generation

The wheel shall be tested according to ASTM E84-90 (Standard Test Method for Surface Burning of Building Materials) and shall achieve the following results:

- 1) Flame spread index = 0
- 2) Smoke developed index = 10

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

D) Desiccant Impregnation

The desiccant shall be evenly impregnated throughout the structure for predictable, consistent performance and for maximum wheel life. Coatings applied on top of the contact medium shall not be acceptable unless the manufacturer can provide independent life tests demonstrating less than a 5% decline in desiccant capacity over a five year period of normal operation.

E) Desiccant Type

The desiccant impregnated into the contact medium shall be:

1) Titanium Reinforced Silica Gel

The Honeycombe® desiccant wheel shall be a fabricated extended surface contact media with a multitude of small passages parallel to the airflow. The rotary structure shall be a monolithic composite consisting of inert silicates with microscopic pores designed to remove water in a vapor phase. The desiccant shall be hydrothermally-stabilized silica gel reinforced with titanium for maximum strength and stability over time. The fabricated structure shall be smooth and continuous having a depth of 400 or 200 millimeters in the direction of airflow without interruptions or sandwich layers which restrict air flow or create a leakage path at joining surfaces. Maximum face velocity shall not exceed 800 fpm. The Honeycombe® wheel shall be manufactured in the United States. The manufacturer shall provide documentation to establish that:

- (a) The desiccant retains more than 90% of its original capacity after ten years of continuous operation in clean air, with inlet air conditions up to and including 100% relative humidity.
- (b) The wheel as impregnated with silica gel is capable of withstanding five complete water immersion cleaning cycles while retaining more than 95% of its original adsorption capacity.

3) Desiccant Wheel Support and Drive Assembly

The wheel shall be a single piece for fast removal and simple handling. In the smaller case, the desiccant wheel shall be supported by four rollers at the base of the unit so the wheel can be easily removed for maintenance by lifting it over the rollers using the drive belt. Center-axle support or any arrangement which requires disassembly of the support structure for wheel removal shall not be acceptable. In addition, the wheel drive assembly shall provide:

A) Rotation Speed

To avoid excessive heat carryover from reactivation to the process air, the wheel rotation speed shall not exceed 16 rph while achieving the required moisture removal rate at the specified conditions.

B) Drive Belt

The drive belt shall be a flat, toothed type, with steel wire reinforcement.

C) Drive Motor

The drive motor shall be fractional horsepower and rated for continuous duty for a period of 20,000 hours under the load conditions imposed by the drive assembly.

D) Rotation Detection

The drive assembly shall be equipped with a rotation detection circuit which shuts down the dehumidifier and signals the operator through an indicating light on the control cabinet if the wheel is not rotating.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

4) Reactivation Circuit

The reactivation circuit shall conform in all respects to the current National Electrical Code

A) Direct Fired Natural Gas Reactivation

- 1) The direct fired raw gas burner shall have a rust-resistant cast iron air-fuel manifold and stainless steel air mixing plates. The burner assembly shall be mounted inside a housing constructed of G-90 hot dipped galvanized steel. The housing shall be equipped with internal insulation of fibrous glass with a minimum thickness of 1 inch.
- 2) Burners with less than 401 MBH input capacity shall be equipped with a single-stage combination gas valve. The complete pilot ignition system shall be A.G.A. design certified to A.N.S.I. Standard Z21.7A-1985" Automatic Intermittent Pilot Ignition Systems for Field Installation. Gas valves and ignition control units shall be A.G.A. design certified (separately) to applicable A.N.S.I. standards:

Z21.15	Manual Gas Valves
Z21.18	Gas Pressure Regulators
Z21.20/Z21.20A	Automatic Ignition Systems
Z21.21/Z21.21A	Automatic Valves
Z21.35	Gas Filters

The modulating valve utilized for gas flow control is a UL recognized component.

- 3) Burners with 401 MBH and greater input capacity shall be equipped with a general-purpose ANSI-standard gas train with redundant safety shutoff valves rated for duty at the specified gas supply pressures.
- 4) Reactivation energy shall be automatically matched to dehumidification requirements by means of a modulating gas valve with proportional electric valve actuator. The valve/actuator assembly shall be connected to a temperature sensor/controller mounted in the discharge of the reactivation air stream.

5) Sensible and Enthalpy Energy Recovery Wheels

- A) The energy recovery wheel shall be made of layers of corrugated and alternating flat composite material or aluminum foil of uniform width to ensure a smooth surface. This wheel material is bonded together to form a rigid transfer medium forming a multitude of narrow channels thus ensuring a laminar flow. The wheels shall be of proven design (available on the market for at least 15 years). Corrosion protected wheels shall be able to withstand environments such as marine/coastal climates or industrial applications.

Sensible wheels shall be non-hygroscopic aluminum wheel for recovering principally sensible heat. When evaporative cooling is used sensible wheel shall be epoxy-treated aluminum wheel for recovering principally sensible heat. Enthalpy wheels shall be hygroscopic aluminum wheel for recovering sensible and latent heat.

The wheel shall be fully wound with an aluminum hub. The wheel shall be cleanable by spraying its face surface with compressed air, low temperature steam or hot water or by vacuum-cleaning without affecting its latent heat recovery properties. The wheels shall be tested in accordance with ASHRAE 84-78 method of testing air-to-air heat exchangers. The wheels shall meet test conditions for European standard and ARI 1060-97. Development and manufacture shall meet all quality assurance criteria specified in BSEN ISO 9001.

B) Casing

The casing shall be constructed as a single-skin, self-supporting, galvanized sheet steel structure and include rotary wheel support beams and a purging sector. The casing shall be supplied with access panels to facilitate inspection and service.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

C) Seals

The casing shall be equipped with adjustable brush seals which minimize carryover to max. 0.05 - 0.2%.

D) Drive

The wheel shall be belt-driven along its perimeter. A constant speed, fractional hp drive motor shall be used. The motor shall be mounted on a self-adjusting base to provide correct belt tension. Moreover it shall include a slow-start feature and automatically index the wheel to keep it clean while the AHU is down or energy recovery isn't required. The drive unit shall be available with a differential thermostat for summer/winter changeover, a speed detector with alarm function and an interface for a central energy management control system and be able to accept all common control signals.

6) Filters

A) Reactivation Filter

The unit shall include a disposable pleated filter with 25% to 30% minimum efficiency with 90% to 92% arrestance minimum as rated by ASHRAE Test Standard 52-76.

B) Standard Medium Efficiency Filters

The unit shall include removable filters at the inlet of both process and reactivation air streams. These filters shall be accessible through access panels. All supply air is filtered through filters of 25% to 30% minimum efficiency with 90% to 92% arrestance minimum as rated by ASHRAE Test Standard 52-76. Filters are disposable 2" deep, pleated type with non-woven media held in place by a welded wire grid. Filters are held in aluminum or galvanized channels top and bottom with spacers and back-up plates to minimize bypass. Filter channels are screwed in place to eliminate air bypass.

7) Fans

A) General Requirements

Blowers provide the specified air volume(s) through the system with adequate static pressure to overcome duct and distribution losses specified. Blowers are of the non-overloading, backward inclined, air foil blade type for air volumes greater than 1000 scfm. Blowers are direct or belt drive provided fan speed does not exceed 80% of the fan shaft critical speed. Access shall be provided on both sides of the supply blower for inspection and servicing. All fans shall be rated in accordance with AMCA Standard 210. Fan motors shall be TEFC, high efficiency type with Class B insulation and a 1.15 service factor.

B) Construction

Fans shall be single width-single inlet (SWSI) housed construction if mounted on exterior of unit housing. Fans shall be single width-single inlet (SWSI) plenum type design if mounted in interior of unit housing.

C) Balancing

Fans shall be balanced after assembly and after coating at the speed the unit is scheduled to operate. Fans are balanced such that the maximum displacement in any plane does not exceed 1.5 mils for fans operating at or below 2000 rpm or 1.0 mils for fans operating above 2000 rpm.

D) Belt Drive Fans

For fan motors of 10 hp and smaller, the belt-drive shall be selected for 120% of rated capacity. For fans driven by motors larger than 10 hp, the drive shall be selected for 150% of rated capacity. All belt-driven fans shall be equipped with:

- 1) Motors mounted on slide rails or bases, belt tension is adjustable.
- 2) Fan assemblies mounted on a rigid structural steel base supported at not less than 4 points by rubber-in-shear or spring type vibration isolators. Overall isolation efficiency is not less than 95% at the design fan speed.
- 3) Fan and base assembly shall be equipped with not less than 3 tie down bolts for stability during shipment to prevent damage.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

E) Direct Drive Fans

Direct drive blowers are 1725 or 3450 rpm and contain an integral fixed blade damper with manual quadrant and locking hardware or adjustable bypass to regulate air volume. Direct drive blowers are mounted on vibration pads or rubber-in-shear type vibration isolators. Overall isolation efficiency is not less than 95% at the design blower speed.

F) Fan Motors

Fan motors shall be the totally-enclosed fan-cooled (TEFC), high-efficiency type with Class B insulation and shall be selected for a service factor of 1.25. Fan motors to be U.L. listed.

8) Chilled Water Cooling Coils

A) Coils shall be sized to provide the full capacity scheduled. Coils shall be arranged to condition the full volume of process air with bypass or balancing dampers as required. Tube water velocities are 7 fps or less and air face velocities are 500 fpm or less. Coil circuiting provides for optimum performance with minimum pressure loss. Coil shall be designed for 250 PSI working pressure and factory tested under water at 300-PSI air pressure.

B) Chilled water coils are fin and tube type, constructed of seamless copper tubes of 5/8-inch diameter with .016 inch wall thickness and aluminum plate type fins of .006 inch thickness, mechanically bonded to tubes. Casing and tube support sheets are 16 gauge galvanized steel formed to provide mounting flanges and structural support for the finned-tube assembly. Supply and return headers are heavy wall copper pipe with vent and drain connections. Supply and return connections are brazed in place with sweat connections for piping. Coils conform to ARI standard 410.

9) Direct Expansion (DX) Cooling Coils

A) Coils shall be sized to provide the full capacity scheduled. Coils shall be arranged to condition the full volume of process air with bypass or balancing dampers as required. Refrigerant pressure drop to be between 1.5 psi and 5 psi. Coil circuiting provides for optimum performance with minimum pressure loss. Coil shall be designed for 250 PSI working pressure and factory tested under water at 300-PSI air pressure.

B) Direct expansion cooling coils are fin and tube type constructed of .016 inch seamless copper tubes and .006 inch thickness aluminum fins mechanically bonded to tubes. Casing and tube support sheets are 16 gauge galvanized steel formed to provide mounting flanges and structural support for the finned-tube assembly. Supply header consists of a distributor to feed liquid refrigerant through seamless copper tubing to all circuits in the coil equally. Tubes are circuited to insure minimum refrigerant pressure drop and maximum heat transfer. Fin spacing of up to 12 FPI provides adequate transfer area to minimum air pressure drop. Coils are mounted for counterflow and have a maximum air face velocity of 500 fpm. Direct expansion coils conform to ARI Standard 410 and are compatible with all other components of the same refrigeration circuit.

10) Drain Pans

A) The drain pan is to be constructed of welded 304 SS and bolted in place. The cooling coil drain pan shall extend the entire length of the coil and extend a minimum of 4 inches beyond the air leaving side of the coil. The drain pan shall be a minimum of 2 inches deep and have a minimum pitch of 1 inch. The drain pan shall be triple sloped to ensure zero standing water. Drain connection shall extend through unit base. Connection to be 1 inch male NPT.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

11) Refrigeration Condensing Units

- A) Condensing units are complete with compressor(s), condenser heat exchanger, receiver tank (if required) and all controls and accessories required to regulate refrigerant pressure, flow rates and temperatures. The condensing unit is piped together with the evaporator coil(s) it serves and is sized and controlled to operate at all conditions required.
- B) Compressors are scroll type (semi-hermetic optional).
- C) All piping connections are brazed using a filler material with not less than 5% silver content for copper to brass joint. Brazing flux is used on all joints and all interior surfaces of brazed assemblies are exposed only to dry nitrogen during heating and cool down periods. All refrigeration tubing is copper, type "L", hard drawn, cleaned and capped, designed specifically for refrigeration service. All piping circuits contain thermostatic expansion valve with external equalization, liquid line and solenoid valve, liquid line sight glass, liquid line filter/dryer (optional replaceable core filter/dryer) with 3-valve bypass, optional hot gas bypass with hot gas regulating valve, solenoid valve, and auxiliary side connector. All components are completely installed in piping circuit and all joints leak tested with refrigerant charge and electronic leak detector prior to evacuation, final charging and complete factory testing and set-up. All assembly and testing work is performed at the factory prior to shipping. All refrigeration circuits are pumped down, valved off and shipped with the full refrigerant charge ready for on site start-up.

12) Indirect Fired Post Heater

- A) Heater shall conform to ANSI Z83.9. Unit shall be suitable for operation on natural gas or propane as specified. Unit shall be of downblast or horizontal configuration. Unit shall have an input rating of 400 MBH on high firing rate and 200 MBH on low firing rate. Where total input is greater than 400 MBH multiple heaters shall be used. It shall contain tube type heated exchangers, flue gas collector with vent fan, in shot burners, and controls for high and low fire. Unit shall be unboxed and fit within the unit housing envelope dimensions.
- B) Burners
Burners shall be die formed in shot type with adjustable air shutters. Burners must be individually removable for cleaning or service. Entire burner assembly must be easily removable as an assembly.
- C) Venting System
Unit shall have a powered venting system consisting of a collection box, direct drive vent fan and an air proving switch. The collection box shall be made of the same material as the heat exchanger bulkhead plate and shall be removable. The venting fan bearings shall have a minimum L10 bearing life of 24000 hrs. The vent fan shall exhaust the flue gas horizontally out the side of the unit. The fan shall operate on 120/1/60 and not exceed 2 FLA.
- D) Heat Exchanger Assembly
Tubes shall be permanently attached to a bulkhead plate to form an airtight seal between combustion byproducts and heated air system. Heat exchanger shall be constructed of 18 gauge aluminized tubes with 14 gauge aluminized steel bulkhead plate. Heat exchanger shall be rated for a minimum lifespan of 100,000 cycles.
- E) Controls
 - 1) Gas train shall utilize components certified by AGA. Gas train shall consist of a 24 VAC two stage combination valve (manual on-off, automatic safety shutoff, regulation to handle 0.5 psig input pressure and adjustable pilot valve). The combination valve shall be rated at a flow of 400 MBH. The valve shall feed inshot burners through a manifold with screw in brass orifices sized for either natural gas or propane as required.

DRYCOOL DEHUMIDIFICATION SYSTEM SPECIFICATIONS

- 2) The flame controller shall be a solid state module that operates on 24 VAC. It shall have a built in spark ignitor and flame sensor with 100% gas shutoff. The pilot shall be ignited during each cycle of operation. After the pilot is proven, the main burner valve shall open. Pilot and main burners shall be extinguished during the off cycle. A thermal disc type high temperature limit switch shall shut off main and pilot valves if an overheat condition occurs.

13) Evaporative Cooler

- A) Unit contains GLASdek® evaporative cooling media, water circulating pump, water drain pump, automatic sump fill valve, and solenoid shutoff valve.

The water sump is monitored by a conductivity sensor to automatically dump and refill water when mineral content gets high. A mist eliminator is used downstream from the media to insure that no water droplets are permitted downstream. Stainless steel and plastic components are used throughout to resist corrosion. Drain and overflow connections are provided on the outside of the unit.

14) Electrical Control Cabinet

The electrical control cabinet shall be weather tight to NEMA 4 standards and shall include:

- A) Wiring to comply with the current National Electrical Code with further fuse and wiring sizing to meet or exceed UL 508A Industrial Control Panel.
- B) Wires shall be color-coded and numbered at both ends and all terminal block connection points shall be numbered. These markings shall correspond with the electrical diagram provided in the operating and maintenance manual.
- C) Components shall be UL or CSA approved.
- D) Control System
The unit sequence of operations shall include separate indication for:
 - 1) Power on
 - 2) Unit running
 - 3) Desiccant wheel rotation fault
 - 4) Burner fault
 - 5) High condensing pressure
 - 6) Motor overload
- E) Operating and Maintenance Manual
The control cabinet shall include a copy of the O&M manual, mounted in a separate compartment or pocket to allow access to critical information by maintenance personnel after installation.
- F) Disconnecting Means
Unit shall have a built in non-fused means of disconnecting from the power supply.

**MUNTERS CORPORATION
DEHUMIDIFICATION DIVISION**

16900 Jordan Road
Selma, TX 78154
TEL: (210) 651-5018 or (800) 229-8557
FAX: (210) 651-9085
URL: www.muntersamerica.com

