


Design, Construct, and Operate to Control Indoor Humidity






Munters is the world leader in dehumidification

Munters is the largest manufacturer of dehumidifiers in the world. Since developing the first desiccant dehumidifier in the late 1930's, Munters has continued to innovate in the fields of dehumidification and energy recovery. Our long history and extensive expertise in dehumidification makes us the premier choice for your dehumidification needs.

Natatoriums have historically posed a difficult environment for the conventional HVAC system. The continuous moisture load swimming pools generate challenges the mechanical system and creates multiple opportunities for structural damage. The combination of humidity and chlorine not only attack the building, but also provide a breeding ground for mold and bacteria which can jeopardize occupant health and comfort. Munters offers a variety of systems in several different sizes, configurations, and thermodynamic process options to meet the customer's needs.



Munters, The Humidity Expert

Our extensive knowledge and experience makes us the premier choice for your dehumidification needs.

Protect the building and its occupants

An efficient HVAC system must function properly during all seasons and be capable of handling all possible indoor and outdoor air conditions—even those abnormal swings. The system should provide precise humidity control because the evaporating water from the pool is continuously released into the air, and must be constantly removed. Space air condition and water temperature must also be balanced for occupant comfort based on the type of pool. (see chart at right).

■ FROM ASHRAE

The recommended conditions for pools as indicated in the ASHRAE Applications Handbook and Humidity Control Design Guide:

| Type of Pool | Air Temp °F | RH% | Water Temp °F |
|---------------|-------------|----------|---------------|
| Recreational | 75 to 85 | 50 to 60 | 75 to 85 |
| Therapeutic | 80 to 85 | 50 to 60 | 85 to 95 |
| Competition | 78 to 85 | 50 to 60 | 76 to 82 |
| Diving | 80 to 85 | 50 to 60 | 80 to 90 |
| Whirlpool/Spa | 80 to 85 | 50 to 60 | 97 to 104 |

Building Design

It is important to start with the correct envelope construction to avoid significant problems during the life of the building. A proper vapor barrier is needed to keep moisture from being trapped in the buildings walls and roof assembly. Additionally care should be taken with regard to the window quantity, design and installation, as well as the wall construction detail and its insulation. Condensation on building elements during low outdoor air temperatures should be carefully guarded against. Please refer to the ASHRAE handbooks and The Humidity Control Design Guide published by ASHRAE for more information on this subject.

Introduce Outside Air into the Building


Outside air must be brought into the space to dilute the chlorine that has evaporated from the pool and to provide fresh air for the occupants.

■ FROM ASHRAE

Standard 62.1 – 2004 calls for:

0.48 CFM PER SQUARE FOOT OF POOL AND DECK AREA & 7.5 CFM PER PERSON IN THE SPECTATOR AREA

In order to make room for this outside air, mechanical exhaust is required. This exhaust should exceed the outdoor air quantity to maintain negative air pressure in the pool area. Pay special attention that the airflow moves in the correct direction. This ensures that humidity and odors will not transfer into adjacent spaces, and also keeps high humidity out of the wall cavities to minimize the potential for condensation.



Prevent Condensation



High humidity and condensation on the building structure can cause significant damage. A detailed dew point analysis of the building is required to eliminate condensation both during initial design and through the end of construction. Thermal bridges in the walls and windows should be analyzed and reviewed carefully to avoid building damage.

Calculate the Loads

TOTAL HUMIDITY LOAD = OA HUMIDITY LOAD + INTERNAL HUMIDITY LOAD + POOL LOAD

Pool Evaporation Rate

■ FROM ASHRAE APPLICATIONS HANDBOOK

Evaporation Rate Equation:

$$\text{POOL LOAD} = 0.1 \times \text{POOL AREA} \times \Delta\text{VAPOR PRESSURE} \times \text{USE FACTOR}$$

Where:

Load = the evaporation rate of the pool (lbs/hr)

Pool Area = the surface area of the water (sq. ft.)

ΔVapor Pressure = the difference in vapor pressure of the air and water (in of Hg)

Use factor = the occupancy factor from ASHRAE.

| Type of Pool | Use Factor |
|------------------------|-------------|
| Residential | 0.5 |
| Fitness Club / Condo | 0.65 |
| Therapy / Elderly Swim | 0.65 |
| Hotel | 0.8 |
| Institutional / School | 0.8 |
| Public Pools | 1.0 |
| Spas and Whirlpools | 1.0 |

Vapor Pressure (Inches of Mercury)

| Fluid Type | Relative Humidity | Temperature °F | | | | | | | | | | | | | |
|------------|-------------------|----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | | 78 | 80 | 82 | 84 | 86 | 88 | 90 | 92 | 94 | 96 | 98 | 100 | 102 | 104 |
| Water | 100% | 0.967 | 1.033 | 1.103 | 1.176 | 1.254 | 1.336 | 1.423 | 1.515 | 1.612 | 1.714 | 1.821 | 1.935 | 2.054 | 2.180 |
| Air | 50% | 0.484 | 0.517 | 0.551 | 0.588 | 0.627 | 0.668 | --- | --- | --- | --- | --- | --- | --- | --- |
| | 60% | 0.581 | 0.620 | 0.662 | 0.706 | 0.753 | 0.802 | --- | --- | --- | --- | --- | --- | --- | --- |

Outside Air Humidity Load

■ FROM ASHRAE APPLICATIONS HANDBOOK

OA Humidity Load Equation: use ASHRAE design dew point conditions:

$$\text{OA HUMIDITY LOAD} = 0.0057 \times \text{OA} \times \Delta\text{HUMIDITY RATIO}$$

Where:

Load = the humidity load of the outside air (lbs/hr)

OACFM = Ventilation Air Quantity (cfm)

ΔHumidity Ratio = the difference in absolute humidity of the outside air and the space (grains/lb)

Properly calculating the internal and external loads of the facility is a critical step in designing a natatorium. The HVAC equipment is sized based on load calculations and the type of facility being constructed. An indoor swimming pool has a remarkable chance of experiencing moisture problems, but with accurate load calculations of the pool evaporation rate, peak outside air loads, and the internal load in the space you can successfully design a healthy and enjoyable natatorium.

Internal Humidity Load

People are an internal load to the space and their activity should be considered in the calculation.

Use the chart below to determine the activity load per hour and add to the pool evaporation load.


| Activity per hour | btu/hr | lbs/hr |
|--------------------------|--------|--------|
| Seated at Rest | 105 | 0.10 |
| Seated Very Light Work | 158 | 0.15 |
| Seated, Light Work | 210 | 0.20 |
| Walking, Standing | 252 | 0.24 |
| Moderate Dancing | 546 | 0.52 |
| Walking Briskly w/Loads | 630 | 0.60 |
| Light Exercise | 872 | 0.83 |
| Medium Athletic Activity | 966 | 0.92 |
| Athletics | 1092 | 1.04 |

Duct Design

The air distribution system should be designed in such a way as to minimize stagnation in the building envelope. While keeping velocity over the pool surface low, air movement is desirable to control chloramines.

Supply air should be washed over windows and other surfaces that may experience low temperatures in cold weather that might lead to condensation. Exhaust and return air inlets should be located high to capture hot and humid air. Whirlpools should have an exhaust air connection directly above.

Ductwork should be aluminum, painted galvanized, 300 series stainless steel or lightweight corrosion resistant fabric. Munters offers DryFlo Ducting. DryFlo ducting is cylindrical tubes constructed of a durable fabric that uniformly disperses air into the space. (See Munters Distribution System illustration above)




Choose pool technology best suited for that region

Weather is a critical component of the building load. When climate is hot and dry, it presents different challenges for a HVAC system than when it is hot and humid. Differing outdoor conditions require specific performances from dehumidification and air conditioning systems. The same type of system throughout the country will not efficiently meet the needs of different area and different climate requirements.

Energy recovery and mechanical dehumidifier requirements are significantly different based on outdoor conditions. In the west, the outdoor condition is generally much lower than the space condition. Outdoor air can naturally be used for indoor dehumidification, and if provided with an efficient energy recovery device, it can be done at significantly

reduced operating costs.

In the east, outdoor air can be used part time for dehumidification and the mechanical dehumidification cycle is only needed for the higher ambient humidity. With colder temperatures in the north, energy recovery for winter operation is easily justified. Depending on the priorities of the user, a significantly different system may be appropriate to maximize energy efficiency.



Munters Offers Different Solutions

Four different types of systems are available to meet both the difficult requirements of the natatorium and the diverse climates these buildings may experience. These different solutions can be optimized to provide the best solution from a first cost, life cycle cost, and sustainability perspective. They allow for the optimization of energy savings and performance.

Selecting the Right System

1 *Where is the building located and what is the local climate?*

Hot and Humid: Southeast U.S.
Humid, but with cold winter climate: Northeast U.S.
Hot and Dry: Southwest U.S.
Dry, but with cold winter climate: Northwest U.S.

2 *What are the priorities of the system required?*

1. Reliability
2. First Cost
3. Operating Cost
4. Increased Ventilation during most of the year

3 *What is the system size requirement?*

Small - < 150 lbs/hr
 Medium - > 150 lbs/hr, < 300 lbs/hr
 Large - > 300 lbs/hr


System Types and Features

| | Wringer Pool | DryCool | Pool Fresh Air | Pool Desiccant |
|-------------|--|----------------------|---|---|
| Climate | Southeast, Northeast, Southwest, Northwest | Southeast, Northeast | Southwest, Northwest | Southeast, Northeast |
| Priority | Reduced compressor runtime for enhanced reliability, Low operating cost, Increased ventilation | Low first cost | Eliminated compressor runtime for enhanced reliability, Low operating cost, Increased ventilation | Reduced compressor runtime for enhanced reliability |
| System Size | Small, Medium, Large | Small, Medium | Small, Medium, Large | Medium, Large |

The system features listed do not outline the extent of the product line availability, rather they outline the features of the systems in competitive environments. See the specific system description on the following pages to see the available capacities of each product.

Heat Pump Option


Wringer Pool and Pool Fresh Air systems are available with the heat pump option to heat the pool water. This option adds an evaporator coil to the exhaust air stream as it leaves the unit to recover the last amount of heat from the building exhaust. This allows the heat pump system to efficiently heat the pool water all year long. The dehumidification cycle is not required to operate and the system is sized based on the energy available in the exhaust air stream. The heat pump is also configurable to provide air heating in the winter whenever sufficient heat is available from the exhaust air stream, and providing very efficient heating of the outside air after it has been preheated by the sensible heat exchanger.



Wringer Pool

Products Description

The Wringer Pool dehumidifier utilizes energy recovery to provide heat recovery in the winter and pre-cool/reheat during the summer. The combination of mechanical dehumidification and outside air dehumidification provides an extremely efficient and reliable dehumidification system. The energy derived from the cooling coils is used to reheat the supply air through a refrigerant reheat coil. During high outdoor humidity the cooling coil acts as the dehumidifier, using the heat exchanger to minimize energy. When the humidity outside is lower than the desired space condition, the unit brings in more outside air to meet the dehumidification load without the need for the cooling coil or compressor run hours, while the heat exchanger recovers the heat from the exhaust air stream to minimize the heating requirement. The unit modulates the outside air to the minimum position during very cold conditions to minimize energy requirements. In addition, a heat pump option can be added to the exhaust air stream to provide pool water and/or supply air heating to increase overall unit efficiency.



Wringer Capacity Chart

| Unit | CFM | Pool Size (sq. ft.) | Dimensions (in.) L x W x H | Weight (lbs.) |
|-------|--------|---------------------|----------------------------|---------------|
| WR 04 | 4,000 | 1,000 - 1,500 | 84 x 66 x 192 | 4,700 |
| WR 06 | 6,000 | 1,500 - 2,250 | 84 x 66 x 192 | 7,400 |
| WR 08 | 8,000 | 2,000 - 3,000 | 84 x 66 x 192 | 9,000 |
| WR 12 | 12,000 | 3,000 - 4,500 | 100 x 74 x 216 | 12,700 |
| WR 18 | 18,000 | 4,500 - 6,750 | 132 x 78 x 234 | 22,000 |
| WR 24 | 24,000 | 6,000 - 9,000 | 144 x 98 x 252 | 27,000 |
| WR 30 | 30,000 | 7,500 - 11,000 | 144 x 114 x 276 | 32,000 |
| WR 40 | 40,000 | 10,000 - 15,000 | 144 x 146 x 312 | 39,000 |
| WR 50 | 50,000 | 12,000 - 18,000 | 144 x 156 x 396 | 44,000 |

Wringer Airflow & Schematic

| State | Summer | | | Winter | | | |
|-------|----------------------|--------|----|--------|--------|-----|--------|
| | Point | CFM | °F | Grains | CFM | °F | Grains |
| A | Return | 10,000 | 84 | 104 | 10,000 | 84 | 77 |
| B | Post Cooling Coil | 9,000 | 93 | 65 | 2,000 | -13 | 2 |
| C | Post Desiccant Wheel | 9,000 | 89 | 65 | 2,000 | 55 | 4 |
| D | Outside Air | 9,000 | 70 | 65 | 2,000 | 55 | 4 |
| E | Supply Air | 9,000 | 70 | 65 | 9,000 | 105 | 61 |

Product Features

- 2" double wall casing
- Sensible counter-flow, cross-flow, and heat pipe heat exchangers with up to 88% efficiency
- Simple dehumidification and energy recovery modes for easy maintenance and control
- Outside air dehumidification mode for reduced compressor run hours
- Increased ventilation throughout many operating hours
- Built in building exhaust fan to maintain negative pressure
- Packaged DX, split system DX, water cooled DX & chilled water options
- DDC microprocessor controls option
- Option for 100% outside air during purge mode
- Stainless steel drain pans
- Heat pump air and water heating available as option
- ETL listed

DryCool Pool

Product Description

The DryCool pool dehumidifier provides energy efficient dehumidification in a small packaged product at low cost. Condenser heat is recovered from the direct expansion refrigeration system to provide the reactivation energy for the desiccant dehumidification process. The cooling energy of the refrigeration system is used to cool and dehumidify the air prior to entering the desiccant wheel. The hybrid refrigerant-desiccant system provides an efficient dehumidifier by eliminating the overcooling required with a refrigeration only based dehumidifier. The system uses the reactivation fan as the exhaust air fan to maintain negative pressure in the space while further enhancing efficiency and minimizing the unit footprint and cost.



DRYCOOL Airflow & Schematic

| State | Summer | | | Winter | | |
|------------------------|--------|----|--------|--------|----|--------|
| Point | CFM | °F | Grains | CFM | °F | Grains |
| A Return | 6,000 | 82 | 100 | 6,000 | 82 | 100 |
| B Post Cooling Coil | 6,000 | 51 | 56 | 6,000 | 82 | 100 |
| C Post Desiccant Wheel | 6,000 | 69 | 34 | 6,000 | 82 | 100 |
| D Outside Air | 4,000 | 95 | 120 | 4,000 | 20 | 10 |
| E Supply Air | 10,000 | 79 | 68 | 10,000 | 90 | 64 |

Product Features

- Foam injected 2" double wall casing
- Desiccant enhanced process for lower connected tonnage and lower operating cost
- Packaged DX, split system DX, water cooled DX and chilled water options
- Coated cooling coils and other critical components
- DDC microprocessor controls
- Option for 100% outside air during purge mode
- Stainless steel drain pans
- ETL listed

DryCool Pool Capacity

| Unit | Maximum CFM | | | Minimum Exhaust | Maximum Exhaust | Tons | Dehumid lbs/hr | Dimensions L x W x H | Weight Pounds |
|------------|-------------|--------|--------|-----------------|-----------------|------|----------------|----------------------|---------------|
| | OA | Return | Total | | | | | | |
| HCU-V 1005 | 1,000 | 1,200 | 2,200 | 250 | 1,200 | 5 | 40 lbs/hr | 58 x 43 x 61 | |
| HCUc-2410 | 1,350 | 2,400 | 3,750 | 500 | 1,500 | 10 | 70 lbs/hr | 178 x 65 x 57 | 3,500 |
| HCUc-3412 | 2,250 | 3,400 | 5,650 | 833 | 2,500 | 12 | 90 lbs/hr | 178 x 65 x 57 | 3,500 |
| HCUc-3415 | 2,700 | 3,400 | 6,100 | 1,000 | 3,000 | 15 | 105 lbs/hr | 178 x 65 x 57 | 3,500 |
| HCUc-4015 | 2,700 | 4,000 | 6,700 | 1,000 | 3,000 | 15 | 115 lbs/hr | 193 x 65 x 72 | 4,250 |
| HCUc-4020 | 2,700 | 4,000 | 7,600 | 1,333 | 4,000 | 20 | 145 lbs/hr | 193 x 65 x 72 | 4,250 |
| HCUc-6020 | 3,600 | 6,000 | 9,600 | 1,333 | 4,000 | 20 | 160 lbs/hr | 226 x 86 x 70 | 5,250 |
| HCUc-6030 | 5,400 | 6,000 | 11,400 | 2,000 | 6,000 | 30 | 225 lbs/hr | 226 x 86 x 70 | 5,250 |
| HCUc-8030 | 5,400 | 8,000 | 13,400 | 2,000 | 6,000 | 30 | 240 lbs/hr | 249 x 96 x 86 | 7,850 |
| HCUc-8040 | 7,200 | 8,000 | 15,200 | 2,667 | 8,000 | 40 | 315 lbs/hr | 249 x 96 x 86 | 7,850 |

Capacity based on 82F 60% RH space condition

Pool Fresh Air


Products Description

The Pool Fresh Air unit is an enhanced energy recovery system. The core of the unit is an efficient sensible energy recovery heat exchanger. The chart below shows that outdoor air can be used to provide dehumidification for natatorium environments effectively up to approximately 60°F dew point. The outdoor air supply can be modulated to provide the correct dehumidification capacity and to not over-dehumidify when possible. In western or similar climates, the 60°F dew point condition is rarely exceeded. This allows the system to maintain the desired space humidity most of the time with no need for mechanical dehumidification. On occasion when it is exceeded the resultant increase in space humidity is small. Temperature and humidity in the space will exceed the design condition for a short period of time, but the trade off is a simplified unit design with no refrigeration system. Cooling can be provided with indirect evaporative cooling, enhancing the system performance and efficiency. Direct evaporative humidification can be added to the supply air. This will minimize the evaporation rate of the pool and the chemical requirements for pool maintenance. Simple, low operating cost, low maintenance, and improved air quality through increased ventilation make the Pool Fresh Air unit an attractive option for natatoriums.

Outdoor Air Dehumidification

| Outside Dew Point Temp. °F | OA CFM | lbs of H ₂ O Removed | OA CFM | lbs of H ₂ O Removed | OA CFM | lbs of H ₂ O Removed |
|----------------------------|--------|---------------------------------|--------|---------------------------------|--------|---------------------------------|
| 0 | 5,000 | 302 | 10,000 | 605 | 20,000 | 1,210 |
| 5 | 5,000 | 297 | 10,000 | 595 | 20,000 | 1,189 |
| 10 | 5,000 | 290 | 10,000 | 581 | 20,000 | 1,162 |
| 15 | 5,000 | 282 | 10,000 | 564 | 20,000 | 1,128 |
| 20 | 5,000 | 271 | 10,000 | 543 | 20,000 | 1,085 |
| 25 | 5,000 | 258 | 10,000 | 517 | 20,000 | 1,034 |
| 30 | 5,000 | 242 | 10,000 | 484 | 20,000 | 968 |
| 35 | 5,000 | 223 | 10,000 | 447 | 20,000 | 894 |
| 40 | 5,000 | 202 | 10,000 | 404 | 20,000 | 808 |
| 45 | 5,000 | 177 | 10,000 | 354 | 20,000 | 707 |
| 50 | 5,000 | 147 | 10,000 | 293 | 20,000 | 587 |
| 55 | 5,000 | 111 | 10,000 | 222 | 20,000 | 444 |
| 60 | 5,000 | 69 | 10,000 | 138 | 20,000 | 276 |
| 65 | 5,000 | 19 | 10,000 | 39 | 20,000 | 78 |


Note: Based on space condition of 82°F, 60% RH.



| State Point | Summer | | | Winter | | |
|------------------------|--------|----|--------|--------|----|--------|
| | CFM | °F | Grains | CFM | °F | Grains |
| A Return | 10,500 | 84 | 104 | 10,500 | 84 | 77 |
| B Post Cooling Coil | 2,000 | 95 | 118 | 2,000 | 0 | 4 |
| C Post Desiccant Wheel | 7,000 | 61 | 80 | 2,000 | 0 | 4 |
| D Outside Air | 7,000 | 68 | 80 | 2,000 | 71 | 4 |
| E Supply Air | 10,000 | 76 | 80 | 10,000 | 98 | 55 |

Product Features



- 2" double wall casing
- Optional indirect evaporative cooling to provide cooling during high ambient temperatures
- Optional direct evaporative cooling to minimize pool evaporation during low dew point conditions
- Sensible counter-flow, cross-flow, and heat pipe heat exchangers with up to 88% efficiency
- Simple dehumidification and energy recovery modes for easy maintenance and control
- Outside air dehumidification mode eliminating compressors
- Increased ventilation throughout many operating hours
- DDC microprocessor controls option
- Option for 100% outside air during purge mode
- Heat pump air and water heating available as option
- ETL listed



Pool Desiccant

Products Description

The Pool Desiccant unit utilizes a silica gel desiccant dehumidification wheel with gas fired reactivation to provide dehumidification without the need for compressorized refrigeration. Cooling coil operation is only required to provide temperature reduction in the space during high ambient temperatures. The wheel turns at a slow 0.1 rpm minimizing maintenance. The desiccant process heats and dehumidifies the supply air reducing the heating required in the heating mode. The effect of this process provides low relative humidity inside the unit and therefore reduced corrosion. Great flexibility and reliability are provided in a packaged large capacity unit.



| State | Summer | | | Winter | | | |
|-------|----------------------|--------|-----|--------|--------|-----|--------|
| | Point | CFM | °F | Grains | CFM | °F | Grains |
| A | Return | 10,000 | 80 | 100 | 10,000 | 82 | 100 |
| B | Post Desiccant Wheel | 10,000 | 119 | 54 | 10,000 | 82 | 100 |
| C | Post Heating Coil | 10,000 | 119 | 54 | 10,000 | 125 | 100 |
| D | Post Cooling Coil | 10,000 | 65 | 54 | 10,000 | 125 | 100 |
| E | Outside Air | 5,000 | 95 | 120 | 5,000 | 20 | 10 |
| F | Supply Air | 15,000 | 75 | 76 | 15,000 | 90 | 70 |

Product Features

- Foam injected 2" double wall casing
- Desiccant dehumidification process for lower connected tonnage and lower compressor run hours
- Low relative humidity during dehumidification process for reduced corrosion
- Packaged DX, split system DX, water cooled DX and chilled water options
- Coated cooling coils and other critical components
- DDC microprocessor controls option
- Option for 100% outside air during purge mode
- Stainless steel drain pans
- ETL listed

Pool Desiccant Capacity Chart

| Unit | Maximum CFM | | | Minimum Exhaust | Maximum Exhaust | Tons | Dehumid lbs/hr | Dimensions L x W x H | Weight Pounds |
|--------|-------------|--------|--------|-----------------|-----------------|------|----------------|----------------------|---------------|
| | OA | Return | Total | | | | | | |
| DDS 20 | 10,000 | 10,000 | 12,000 | 250 | 10,000 | 100 | 250 lbs/hr | 219 x 80 x 70 | 6,500 |
| DDS 30 | 30,000 | 30,000 | 30,000 | 500 | 15,000 | 200 | 350 lbs/hr | 219 x 96 x 101 | 8,500 |
| DDS 40 | 50,000 | 50,000 | 50,000 | 1,000 | 25,000 | 300 | 500 lbs/hr | 280 x 134 x 101 | 10,500 |

Economic Evaluation and Life Cycle Cost

Munters has software tools to analyze the operating cost of each system. Unit selection and cost data are inputted with design parameters, local weather data, and energy costs. The output is annual energy cost, annual energy savings, and simple payback.

\$5,000 vs. \$16,000

Operating Cost of Munters Pool Fresh Air Product

| Location | | | | Chicago, IL | Change Over Dew Point | | | | 58.3 | Cooling Equipment C.O.P. | | | | 3 |
|---|-------------|-------|----------------------------|-------------|---|-------------------|-------------------------------|---------------------------|---|--------------------------|-----------------------------|-----------------------------|---------------------|-----------|
| Supply CFM | | | | 20,000 | Heat Recovery Effectiveness | | | | 65.0 | Summer Building Load | | | | 119 MBH |
| Required Supply Air Humidity Ratio | | | | 0.0121 | Cooling Fuel Cost | | | | \$0.100/kwh=\$9.77/Million BTU of Cooling Input | Winter Building Load | | | | 189 MBH |
| Summer Outside Air | | | | 5,000 | Cost of Heating Fuel | | | | \$1.00/1,000,000 BTU | Max Evaporation Rate | | | | 198 #/Hr. |
| Return Air Temperature | | | | 82 | Efficiency of Fuel Conversion (Heating) | | | | 80 | DX LAT | | | | 50.2 °F |
| Return Air Relative Humidity | | | | 60 | Outside Air CFM at Change Over | | | | 12,000 | | | | | |
| Dry Bulb | Temp. MCWB* | DP | Total Hours.* at Condition | Outside Air | Dehumid Coil Tons | Dehumid Coil Cost | Condenser Heat Available BTUH | Required Supply Air Temp. | No Heat Supply Air Temp. | Cost to Heat Supply Air | Condenser Air Reheat Credit | Condenser Water Heat Credit | Dollars Spent Total | |
| 120 | 75 | 63.3 | 0 | 5,000 | 27.64 | \$0 | 414,652 | 73.2 | 74.1 | \$0 | \$0 | \$0 | \$0 | |
| 97 | 76 | 67.6 | 6 | 5,000 | 31.03 | \$22 | 465,418 | 74.3 | 74.1 | \$0 | \$0 | \$1.66 | \$20.16 | |
| 92 | 74 | 66.4 | 58 | 5,000 | 28.99 | \$197 | 434,864 | 75.4 | 74.1 | \$2 | \$2 | \$16.06 | \$181.01 | |
| 87 | 72 | 65.4 | 165 | 5,000 | 27.11 | \$524 | 406,969 | 76.5 | 74.1 | \$11 | \$11 | \$45 | \$478.63 | |
| 82 | 70 | 64.5 | 324 | 5,000 | 25.38 | \$964 | 380,774 | 78.3 | 74.1 | \$38 | \$38 | \$89.70 | \$874.24 | |
| 77 | 67 | 62.0 | 487 | 5,000 | 20.81 | \$1,188 | 312,183 | 79.8 | 74.1 | \$75 | \$75 | \$114.66 | \$1,073.22 | |
| 72 | 64 | 59.6 | 681 | 5,000 | 16.54 | \$1,320 | 248,038 | 82.0 | 74.1 | \$147 | \$147 | \$64.29 | \$1,255.49 | |
| 67 | 61 | 57.4 | 759 | 10,001 | 0.00 | \$0 | 0 | 82.6 | 79.4 | \$66 | \$0 | \$0 | \$66.00 | |
| 62 | 57 | 53.7 | 700 | 7,525 | 0.00 | \$0 | 0 | 83.2 | 79.4 | \$72 | \$0 | \$0 | \$72.06 | |
| 57 | 52 | 48.0 | 604 | 5,729 | 0.00 | \$0 | 0 | 83.7 | 79.5 | \$70 | \$0 | \$0 | \$69.60 | |
| 52 | 47 | 42.3 | 581 | 4,766 | 0.00 | \$0 | 0 | 84.3 | 79.5 | \$76 | \$0 | \$0 | \$76.04 | |
| 47 | 43 | 38.7 | 565 | 4,380 | 0.00 | \$0 | 0 | 84.9 | 79.3 | \$86 | \$0 | \$0 | \$85.61 | |
| 42 | 38 | 32.8 | 572 | 3,934 | 0.00 | \$0 | 0 | 85.5 | 79.2 | \$97 | \$0 | \$0 | \$96.78 | |
| 37 | 34 | 29.9 | 725 | 3,756 | 0.00 | \$0 | 0 | 86.1 | 79.0 | \$138 | \$0 | \$0 | \$138.10 | |
| 32 | 30 | 27.0 | 869 | 3,612 | 0.00 | \$0 | 0 | 86.6 | 78.8 | \$184 | \$0 | \$0 | \$183.99 | |
| 27 | 25 | 21.3 | 589 | 3,392 | 0.00 | \$0 | 0 | 87.2 | 78.7 | \$136 | \$0 | \$0 | \$135.66 | |
| 22 | 21 | 18.9 | 371 | 3,322 | 0.00 | \$0 | 0 | 87.8 | 78.5 | \$94 | \$0 | \$0 | \$93.54 | |
| 17 | 16 | 13.3 | 231 | 3,194 | 0.00 | \$0 | 0 | 88.4 | 78.4 | \$63 | \$0 | \$0 | \$62.78 | |
| 12 | 11 | 7.6 | 164 | 3,098 | 0.00 | \$0 | 0 | 89.0 | 78.2 | \$48 | \$0 | \$0 | \$47.88 | |
| 7 | 6 | 1.6 | 115 | 3,026 | 0.00 | \$0 | 0 | 89.5 | 78.0 | \$36 | \$0 | \$0 | \$35.94 | |
| 2 | 1 | -4.7 | 89 | 2,971 | 0.00 | \$0 | 0 | 90.1 | 77.8 | \$30 | \$0 | \$0 | \$29.67 | |
| -3 | -3 | -81.9 | 93 | 2,843 | 0.00 | \$0 | 0 | 90.7 | 77.8 | \$33 | \$0 | \$0 | \$32.64 | |
| Annual Energy Expense \$5,109.04 | | | | | | | | | | | | | | |

Operating Cost of Conventional Refrigeration-Based Pool Dehumidifier as Comparison

| Location | | | | Chicago, IL | Heat Recovery Effectiveness | | | | 0 | Cooling Equipment C.O.P. | | | | 3 |
|--|-------------|-------|----------------------------|-------------|---|-------------------|-------------------------------|---------------------------|---|--------------------------|-----------------------------|-----------------------------|---------------------|-----------|
| Supply CFM | | | | 20,000 | Cooling Fuel Cost | | | | \$0.100/kwh=\$9.77/Million BTU of Cooling Input | Summer Building Load | | | | 180 MBH |
| Required Supply Air Humidity Ratio | | | | 0.0121 | Cost of Heating Fuel | | | | \$1.00/1,000,000 BTU | Winter Building Load | | | | 300 MBH |
| Min Outside Air | | | | 5,000 | Efficiency of Fuel Conversion (Heating) | | | | 80 | Max Evaporation Rate | | | | 198 #/Hr. |
| Return Air Temperature | | | | 82 | Return Air Relative Humidity | | | | 60 | | | | | |
| Dry Bulb | Temp. MCWB* | DP | Total Hours.* at Condition | Outside Air | Dehumid Coil LAT/Tons | Dehumid Coil Cost | Condenser Heat Available BTUH | Required Supply Air Temp. | No Heat Supply Air Temp. | Cost to Heat Supply Air | Condenser Air Reheat Credit | Condenser Water Heat Credit | Dollars Spent Total | |
| 120 | 75 | 63.3 | 0 | 5,000 | 62.1/40.5 | \$0 | 608,142 | 73.7 | 72.1 | \$0 | \$0 | \$0 | \$0 | |
| 97 | 76 | 67.6 | 6 | 5,000 | 60.5/46.9 | \$33 | 703,896 | 74.8 | 69.6 | \$1 | \$1 | \$1.66 | \$31.34 | |
| 92 | 74 | 66.4 | 58 | 5,000 | 60.9/45 | \$307 | 676,459 | 75.8 | 68.7 | \$11 | \$11 | \$16.06 | \$290.50 | |
| 87 | 72 | 65.4 | 165 | 5,000 | 61.3/43.5 | \$842 | 652,889 | 76.9 | 67.8 | \$41 | \$41 | \$45.68 | \$796.50 | |
| 82 | 70 | 64.5 | 324 | 5,000 | 61.7/42.1 | \$1,602 | 632,694 | 77.9 | 66.8 | \$98 | \$98 | \$89.70 | \$1,511.98 | |
| 77 | 67 | 62.0 | 487 | 5,000 | 62.5/38.7 | \$2,211 | 580,941 | 79.0 | 66.2 | \$169 | \$169 | \$134.82 | \$2,075.71 | |
| 72 | 64 | 59.6 | 681 | 5,000 | 63.3/35.7 | \$2,853 | 536,244 | 80.0 | 65.5 | \$268 | \$268 | \$135.71 | \$2,665.17 | |
| 67 | 61 | 57.4 | 759 | 5,000 | 63.9/33.2 | \$2,955 | 498,342 | 81.1 | 64.7 | \$337 | \$337 | \$42.41 | \$2,819.62 | |
| 62 | 57 | 53.7 | 700 | 5,000 | 64.8/29.2 | \$2,397 | 438,289 | 82.1 | 64.2 | \$341 | \$341 | \$0 | \$2,354.74 | |
| 57 | 52 | 48.0 | 604 | 5,000 | 66/24.1 | \$1,711 | 362,567 | 83.2 | 63.8 | \$318 | \$374 | \$0 | \$1,754.98 | |
| 52 | 47 | 42.3 | 581 | 5,000 | 82/0 | \$0 | 0 | 84.2 | 74.5 | \$153 | \$0 | \$0 | \$153.47 | |
| 47 | 43 | 38.7 | 565 | 5,000 | 82/0 | \$0 | 0 | 85.3 | 73.3 | \$185 | \$0 | \$0 | \$184.55 | |
| 42 | 38 | 32.8 | 572 | 5,000 | 82/0 | \$0 | 0 | 86.3 | 72.0 | \$223 | \$0 | \$0 | \$222.57 | |
| 37 | 34 | 29.9 | 725 | 5,000 | 82/0 | \$0 | 0 | 87.4 | 70.8 | \$327 | \$0 | \$0 | \$327.40 | |
| 32 | 30 | 27.0 | 869 | 5,000 | 82/0 | \$0 | 0 | 88.5 | 69.5 | \$447 | \$0 | \$0 | \$446.72 | |
| 27 | 25 | 21.3 | 589 | 5,000 | 82/0 | \$0 | 0 | 89.5 | 68.3 | \$340 | \$0 | \$0 | \$339.58 | |
| 22 | 21 | 18.9 | 371 | 5,000 | 82/0 | \$0 | 0 | 90.6 | 67.0 | \$237 | \$0 | \$0 | \$237.08 | |
| 17 | 16 | 13.3 | 231 | 5,000 | 82/0 | \$0 | 0 | 91.6 | 65.8 | \$162 | \$0 | \$0 | \$162.05 | |
| 12 | 11 | 7.6 | 164 | 5,000 | 82/0 | \$0 | 0 | 92.7 | 64.5 | \$125 | \$0 | \$0 | \$125.29 | |
| 7 | 6 | 1.6 | 115 | 5,000 | 82/0 | \$0 | 0 | 93.7 | 63.3 | \$95 | \$0 | \$0 | \$95.04 | |
| 2 | 1 | -4.7 | 89 | 5,000 | 82/0 | \$0 | 0 | 94.8 | 62.0 | \$79 | \$0 | \$0 | \$79.11 | |
| -3 | -3 | -81.9 | 93 | 5,000 | 82/0 | \$0 | 0 | 95.8 | 60.8 | \$88 | \$0 | \$0 | \$88.48 | |
| Annual Energy Expense \$16,761.40 | | | | | | | | | | | | | | |

*Weather data used for Chicago, IL. Heat exchanger effectiveness is based on dry sensible heat transfer. Condensing within the heat exchanger will increase performance.

Operating Cost of Wringer Pool Product

| Location | | | | Washington DC | Change Over Dew Point | | | | 58.3 | Cooling Equipment C.O.P | | | | 3 |
|---|-------------|-------|----------------------------|---------------|---|-------------------|-------------------------------|---------------------------|--|-------------------------|-----------------------------|-----------------------------|---------------------|-----------|
| Supply CFM | | | | 20,000 | Heat Recovery Effectiveness | | | | 65.0 | Summer Building Load | | | | 60 MBH |
| Required Supply Air Humidity Ratio | | | | 0.0121 | Cooling Fuel Cost | | | | \$0.100/kwh=\$9.77/Million BTU of Cooling Output | Winter Building Load | | | | 200 MBH |
| Summer Outside Air | | | | 5,000 | Cost of Heating Fuel | | | | \$1.00/1,000,000 BTU | Max Evaporation Rate | | | | 198 #/Hr. |
| Return Air Temperature | | | | 82 | Efficiency of Fuel Conversion (Heating) | | | | 80 | DX LAT | | | | 58.3 °F |
| Return Air Relative Humidity | | | | 60 | Outside Air CFM at Change Over | | | | 12,000 | | | | | |
| Dry Bulb | Temp. MCWB* | DP | Total Hours.* at Condition | Outside Air | Dehumid Coil Tons | Dehumid Coil Cost | Condenser Heat Available BTUH | Required Supply Air Temp. | No Heat Supply Air Temp. F° | Cost to Heat Supply Air | Condenser Air Reheat Credit | Condenser Water Heat Credit | Dollars Spent Total | |
| 120 | 77 | 67.1 | 0 | 5,000 | 43.66 | \$0 | 327,485 | 79.2 | 76.4 | \$0 | \$0 | \$0 | \$0 | |
| 97 | 76 | 67.6 | 6 | 5,000 | 41.89 | \$29 | 327,485 | 79.2 | 76.4 | \$1 | \$1 | \$0 | \$29.46 | |
| 92 | 74 | 66.4 | 72 | 5,000 | 38.40 | \$324 | 327,485 | 80.4 | 76.4 | \$8 | \$8 | \$0 | \$324.01 | |
| 87 | 72 | 65.4 | 243 | 5,000 | 35.05 | \$998 | 327,485 | 80.9 | 76.4 | \$30 | \$30 | \$0 | \$998.35 | |
| 82 | 70 | 64.5 | 428 | 5,000 | 31.86 | \$1,598 | 327,485 | 81.5 | 76.4 | \$59 | \$59 | \$0 | \$1,598.11 | |
| 77 | 68 | 63.7 | 631 | 5,000 | 28.80 | \$2,130 | 327,485 | 82.1 | 76.4 | \$97 | \$97 | \$0 | \$2,130.02 | |
| 72 | 66 | 63.0 | 925 | 5,000 | 25.88 | \$2,805 | 327,485 | 82.7 | 76.4 | \$157 | \$157 | \$0 | \$2,805.21 | |
| 67 | 61 | 57.4 | 858 | 10,001 | 0.00 | \$0 | 0 | 83.2 | 79.9 | \$77 | \$0 | \$0 | \$77.48 | |
| 62 | 56 | 51.8 | 755 | 6,779 | 0.00 | \$0 | 0 | 83.8 | 80.1 | \$76 | \$0 | \$0 | \$75.73 | |
| 57 | 51 | 46.0 | 688 | 5,325 | 0.00 | \$0 | 0 | 84.4 | 80.1 | \$79 | \$0 | \$0 | \$79.01 | |
| 52 | 47 | 40.0 | 671 | 4,508 | 0.00 | \$0 | 0 | 84.9 | 80.1 | \$88 | \$0 | \$0 | \$87.98 | |
| 47 | 42 | 36.3 | 665 | 4,175 | 0.00 | \$0 | 0 | 85.5 | 80.0 | \$100 | \$0 | \$0 | \$100.24 | |
| 42 | 37 | 30.3 | 734 | 3,781 | 0.00 | \$0 | 0 | 86.1 | 79.9 | \$123 | \$0 | \$0 | \$123.42 | |
| 37 | 33 | 27.3 | 708 | 3,625 | 0.00 | \$0 | 0 | 86.7 | 79.7 | \$133 | \$0 | \$0 | \$133.20 | |
| 32 | 29 | 24.1 | 621 | 3,492 | 0.00 | \$0 | 0 | 87.2 | 79.6 | \$129 | \$0 | \$0 | \$129.15 | |
| 27 | 24 | 17.8 | 362 | 3,295 | 0.00 | \$0 | 0 | 87.8 | 79.5 | \$82 | \$0 | \$0 | \$81.80 | |
| 22 | 19 | 11.0 | 212 | 3,152 | 0.00 | \$0 | 0 | 88.4 | 79.4 | \$52 | \$0 | \$0 | \$51.82 | |
| 17 | 15 | 8.9 | 101 | 3,117 | 0.00 | \$0 | 0 | 88.9 | 79.2 | \$27 | \$0 | \$0 | \$26.77 | |
| 12 | 10 | 2.0 | 51 | 3,030 | 0.00 | \$0 | 0 | 89.5 | 79.0 | \$14 | \$0 | \$0 | \$14.49 | |
| 7 | 6 | 1.6 | 13 | 3,026 | 0.00 | \$0 | 0 | 90.1 | 78.8 | \$4 | \$0 | \$0 | \$3.97 | |
| 2 | 1 | -4.7 | 1 | 2,971 | 0.00 | \$0 | 0 | 90.6 | 78.7 | \$0 | \$0 | \$0 | \$0.32 | |
| -3 | -4 | -81.9 | 0 | 2,843 | 0.00 | \$0 | 0 | 91.2 | 78.6 | \$0 | \$0 | \$0 | \$0 | |
| Annual Energy Expense \$8,870.54 | | | | | | | | | | | | | | |

Operating Cost of Conventional Refrigeration-Based Pool Dehumidifier as Comparison

| Location | | | | Washington DC | Heat Recovery Effectiveness | | | | 0 | Cooling Equipment C.O.P | | | | 3 |
|--|-------------|-------|----------------------------|---------------|---|-------------------|-------------------------------|---------------------------|---|-------------------------|-----------------------------|-----------------------------|---------------------|-----------|
| Supply CFM | | | | 20,000 | Cooling Fuel Cost | | | | \$0.100/kwh=\$9.77/Million BTU of Cooling Input | Summer Building Load | | | | 180 MBH |
| Required Supply Air Humidity Ratio | | | | 0.0121 | Cost of Heating Fuel | | | | \$1.00/1,000,000 BTU | Winter Building Load | | | | 300 MBH |
| Min Outside Air | | | | 5,000 | Efficiency of Fuel Conversion (Heating) | | | | 80 | Max Evaporation Rate | | | | 198 #/Hr. |
| Return Air Temperature | | | | 82 | Return Air Relative Humidity | | | | 60 | | | | | |
| Dry Bulb | Temp. MCWB* | DP | Total Hours.* at Condition | Outside Air | Dehumid Coil Tons | Dehumid Coil Cost | Condenser Heat Available BTUH | Required Supply Air Temp. | No Heat Supply Air Temp. F° | Cost to Heat Supply Air | Condenser Air Reheat Credit | Condenser Water Heat Credit | Dollars Spent Total | |
| 120 | 75 | 63.3 | 0 | 5,000 | 62.1/40.5 | \$0 | 608,142 | 73.7 | 72.1 | \$0 | \$0 | \$0 | \$0 | |
| 97 | 76 | 67.6 | 6 | 5,000 | 60.5/46.9 | \$33 | 703,896 | 74.8 | 69.6 | \$1 | \$1 | \$1.66 | \$31.34 | |
| 92 | 74 | 66.4 | 72 | 5,000 | 60.9/45 | \$381 | 676,459 | 75.8 | 67.8 | \$14 | \$14 | \$19.93 | \$360.62 | |
| 87 | 72 | 65.4 | 243 | 5,000 | 61.3/43.5 | \$1,240 | 652,889 | 76.9 | 66.8 | \$60 | \$60 | \$67.25 | \$1,172.33 | |
| 82 | 70 | 64.5 | 428 | 5,000 | 61.7/42.1 | \$2,116 | 632,694 | 77.9 | 65.8 | \$129 | \$129 | \$118.49 | \$1,997.31 | |
| 77 | 68 | 63.7 | 631 | 5,000 | 62/41 | \$3,034 | 615,350 | 79.0 | 64.7 | \$226 | \$226 | \$174.69 | \$2,859.12 | |
| 72 | 66 | 63.0 | 925 | 5,000 | 62.2/40.1 | \$4,347 | 601,517 | 80.0 | 64.7 | \$385 | \$385 | \$256.08 | \$4,091.29 | |
| 67 | 61 | 57.4 | 858 | 5,000 | 63.9/33.2 | \$3,341 | 498,342 | 81.1 | 64.5 | \$381 | \$381 | \$153.41 | \$3,187.39 | |
| 62 | 56 | 51.8 | 755 | 5,000 | 65.3/27.4 | \$2,426 | 411,333 | 82.1 | 64.1 | \$361 | \$361 | \$26.75 | \$2,399.73 | |
| 57 | 51 | 46.0 | 688 | 5,000 | 66.4/22.5 | \$1,822 | 338,867 | 83.2 | 63.8 | \$357 | \$291 | \$0 | \$1,887.00 | |
| 52 | 46 | 40.0 | 671 | 5,000 | 82/0 | \$0 | 0 | 84.2 | 74.5 | \$177 | \$0 | \$0 | \$177.25 | |
| 47 | 42 | 36.3 | 665 | 5,000 | 82/0 | \$0 | 0 | 85.3 | 73.3 | \$217 | \$0 | \$0 | \$217.21 | |
| 42 | 37 | 30.3 | 734 | 5,000 | 82/0 | \$0 | 0 | 86.3 | 72.0 | \$289 | \$0 | \$0 | \$285.60 | |
| 37 | 33 | 27.3 | 708 | 5,000 | 82/0 | \$0 | 0 | 87.4 | 70.8 | \$320 | \$0 | \$0 | \$319.72 | |
| 32 | 29 | 24.1 | 621 | 5,000 | 82/0 | \$0 | 0 | 88.5 | 69.5 | \$319 | \$0 | \$0 | \$319.23 | |
| 27 | 24 | 17.8 | 362 | 5,000 | 82/0 | \$0 | 0 | 89.5 | 68.3 | \$209 | \$0 | \$0 | \$208.71 | |
| 22 | 19 | 11.0 | 212 | 5,000 | 82/0 | \$0 | 0 | 90.6 | 67.0 | \$135 | \$0 | \$0 | \$135.47 | |
| 17 | 15 | 8.9 | 101 | 5,000 | 82/0 | \$0 | 0 | 91.6 | 65.8 | \$71 | \$0 | \$0 | \$70.85 | |
| 12 | 10 | 2.0 | 51 | 5,000 | 82/0 | \$0 | 0 | 92.7 | 64.5 | \$39 | \$0 | \$0 | \$38.96 | |
| 7 | 6 | 1.6 | 13 | 5,000 | 82/0 | \$0 | 0 | 93.7 | 63.3 | \$11 | \$0 | \$0 | \$10.74 | |
| 2 | 1 | -4.7 | 1 | 5,000 | 82/0 | \$0 | 0 | 94.8 | 62.0 | \$1 | \$0 | \$0 | \$0.89 | |
| -3 | -4 | -81.9 | 0 | 5,000 | 82/0 | \$0 | 0 | 95.8 | 60.8 | \$0 | \$0 | \$0 | \$0 | |
| Annual Energy Expense \$19,770.76 | | | | | | | | | | | | | | |

*Weather data used for Washington, DC.

Heat exchanger effectiveness is based on dry sensible heat transfer. Condensing within the heat exchanger will increase performance.

\$8,000 vs. \$19,000

This two-page comparison allows the designer and end user to make intelligent decisions regarding system configuration and payback criteria. Together, Munters can assist in selecting the correct systems and options to meet the customers needs and desires.



Munters Flexibility

Natatoriums vary in size, shape, and location. Some are low, small rooms, others are atriums of hotels with vast deck areas and high ceilings. Some are totally interior with no transmission load, while others are completely enclosed in glass with large transmission loads. Munters provides a standard or customized product for precise application for any amount and proportion of sensible and latent capacity to meet the load. Munters provides systems with increased outside air throughout the year to improve indoor air quality, while reducing the air to minimum required airflows during extreme temperatures to minimize operating cost.



16900 Jordan Road
Selma, TX 78154
Tel: 210-651-5018 or 800-229-8557 Fax: 210-651-9085
www.munters.us